



- NOTE:
- 1) Files are not shown for clarity. See sheets 23 & 24.
  - 2) Eyebolts and Eyebolt anchor assemblies shall be capable of sustaining a 3000 lbs working loading.
  - 3) Contractor shall furnish one 1 1/2 ton portable Gantry crane complete with chain hoist (1 1/2 ton). Crane and chain hoist shall conform to applicable CMAA standards.

**BASEMENT FLOOR PLAN @ ELEV. 445**  
 Scale: 3/8" = 1'-0"

EPA PROJECT NO. C291090		Rev. 2-82 MKK	
<b>GBA</b> GEORGE BUTLER ASSOCIATES CONSULTING ENGINEERS/ARCHITECTS LANDSCAPE ARCHITECTS/PLANNERS	OFFICES: SUITE 305 A FAIRWAY OFFICE CENTER 4310 JOHNSON DRIVE / SHANNEE MISSION / KANSAS 66209 1100 CITY CENTER SQUARE 1100 MAIN / KANSAS CITY / MISSOURI 64105 SUITE 134 LAKESIDE PLAZA II 6700 CORPORATE DRIVE / KANSAS CITY / MISSOURI 64120		
	WASTEWATER TREATMENT PLANT EXPANSION <b>BIO-FILTER BUILDING</b> <b>BASEMENT FLOOR PLAN</b> CITY OF O'FALLON, MISSOURI		
	DESIGNED BY: N.C.C.	DRAWN BY: C. Roja	CHECKED BY: W.A.C.