

Results of Facing Stability Static Analysis

SRW Unit #	Heel Elev (ft)	Geosynthetic Product	FOS Crest Toppling ≥ 1.50	FOS Connection ≥ 1.50
21	13.33	Miragrid 3XT	8.50	14.91
18	11.33	Miragrid 3XT		7.16
15	9.33	Miragrid 3XT		5.13
12	7.33	Miragrid 3XT		4.21
9	5.33	Miragrid 3XT		3.69
6	3.33	Miragrid 3XT		3.35
3	1.33	Miragrid 3XT		2.60
