

GRADING NOTES

1. Siltation control will be provided as required to prevent

2. Siltation control shall be silt fence and/or straw bales placed end to end and anchored with no less than 3' long x 2"x1" wooden stakes. Upon completion of storm sewers, straw bales shall be placed on all sides of structures and shall remain

3. All straw bales must be countersunk a minimum of 3" and additional straw bales shall be placed at the direction

The contractor shall field investigate the entire site prior to his bid submittal noting the existing vegetation and trees and including the removal and disposal of same

No area shall be cleared without permission of the

grade shall be within 0.2 feet more or less of those

The contractor shall restore offsite construction areas to an equal or better condition than existed prior to

Earth subgrade for paved areas must be compacted to a minimum 90% of maximum dry density as determined by the Modified AASHTO T-180 Compaction Test or 95% of maximum density as determined by the Standard Proctor Test AASHTO T-99 ill filled places in proposed roads shall be compacted from the pottom of the fill up. All test shall be verified by a soils engineer concurrent with grading and backfilling operations and must be approved by a City Representative before paving may commence. Owner to provide a copy of the soils report to the grading contractor. Contractor shall be responsible for adhering to all ecommendations outlined in the soils report.

Tall Fescue(TF) & Smooth Brome(SB) between March 1st and June 1st. at a rate of TF=30lbs/AC & SB=20lsb/AC Regulations for Urban Development.

Proposed phasing of development (rough dates) including

Grading and construction

installation of temporary sediment control, storm drainage, paving),

Final Grading and Landscaping

Where natural vegetation is removed during grading, vegetation shall be re-established in such a density as to prevent erosion. Permanent type grasses shall be established as soon as possible or during the next seeding period after grading has been completed. Refer to Appendix A of St. Charles Soil and Water Conservation District - Model Sediment and Erasion Control

When grading operations are completed or suspended for more than 14 days, permanent grass must be established at sufficient density to provide erosion control on the site. Between permanent grass seeding periods, temporary cover shall be provided according to the designated officials recommendation. Refer to Appendix A of St Charles Soil and Water Conservation District - Model Sediment and Erosion Control Regulations.

14. Developer must supply City construction inspectors with soils reports prior to or during site soil testing.

15. Erosion control systems shall be inspected and necessary corrections made within 24 hours of any rainstorm resulting in one-half inch of rain or more.

Rip rap shown at flared ends will be evaluted in the feild after installation for effectiveness and field modified if necessary to reduce

17. All filled places under proposed roads, proposed sanitary and storm sewer lines, and/or paved areas including trench backfills shall be compacted to 90% of maximum density as determined by the "Modified AASHTO T-180 Compaction" Test" or 95% of maximum density as determined by the Standard Proctor Test AASHTO T-99. All filled placed in proposed roads shall be compacted from the bottom of the fill up. All tests shall be verified by a soils engineer concurrent with grading and backfilling operations. Ensure the moisture content of the soil in fill areas is to correspond to the compactive effort as defined by the Standard or Modified Proctor Test. Optimum moisture content shall be determined using the same test that was used for compaction. Soil compaction curves shall be submitted to the City of O'Fallon prior to the placement of fill. Proof rolling may be required to verify soil stability at the discretion of the City of O'Fallon.

Developer must supply city construction inspectors with soil reports prior to or during site soil testing. The soil report will be required to contain the following information on soil test curves (Procter reports) for projects within the city:

Maximum dry density Optimum moisture content

Maximum and minimum allowable moisture content Curve must be plotted to show density from a minimum of 90% compaction and above as determined by the "Modified AASHTO T-180 Compaction Test" (A.S.T.M.-D-1157) or from a minumum of 95% as determined by the "Standard Procter Test ASSHTO T-99, Method C" (A.S.T.M.-D-698). Proctor type must be

Curve must have at least 5 density points with moisture content and sample

locations listed on document. Specific gravity

Natural Moisture content

Be adviced that if this information is not provided to the City's Construcion Inspector the City will not allow grading or construction activities to proceed on any project site. EROSION AND SEDIMENT CONTROL NOTES:

EROSION AND SILTATION CONTROL SHALL BE INSTALLED PRIOR TO ANY GRADING AND BE MAINTAINED THROUGHOUT THE PROJECT UNTIL ACCEPTANCE OF THE WORK BY THE OWNER AND/OR CONTROLLING REGULATORY AGENCY AND ADEQUATE VEGETATIVE GROWTH INSURES NO FURTHER EROSION OF THE SOIL.

TEMPORARY SILTATION CONTROL MEASURES (STRUCTURAL) SHALL BE MAINTAINED UNTIL VEGETATIVE COVER IS ESTABLISHED AT A SUFFICIENT DENSITY TO PROVIDE EROSION CONTROL ON THE SITE.

ALL FINISHED GRADES (AREAS NOT TO BE DISTURBED BY FUTURE IMPROVEMENT) IN EXCESS OF 20% SLOPES (5:1) SHALL BE MULCHED AND TACKED AT THE RATE OF 100 POUNDS PER 1,000 SQUARE FEET WHEN SEEDED.

4. STORM WATER PIPES, OUTLETS AND CHANNELS SHALL BE PROTECTED BY SILT BARRIERS AND KEPT FREE OF WASTE AND SILT AT ALL TIMES PRIOR TO FINAL SURFACE STABILIZATION AND/OR PAVING.

5. SILTATION FENCES SHALL BE INSPECTED PERIODICALLY FOR DAMAGE AND FOR THE AMOUNT OF SEDIMENT WHICH HAS ACCUMULATED. REMOVAL OF SEDIMENT WILL BE REQUIRED WHEN IT REACHES 1/2 THE HEIGHT OF THE SILTATION FENCE.

6. SITE SHALL SHEET DRAIN DURING GRADING OPERATIONS SIMILAR TO EXISTING CONDITIONS. NO ADDITIONAL TEMPORARY DRAINAGE WAYS WILL BE NECESSARY TO ADEQUATELY FILE #3203.05

HANDLE DRAINAGE DURING GRADING OPERATIONS. NOT APPROVED FOR CONSTRUCTION

KE VISIONS	
DATE	
90-60-10	01-09-06 PER CITY OF O'FALLON
1.16.06	REVISED PER T.R. HUGHES
05-06-06	REVISED PER T.R. HUGHES
02-21-06	PER CITY OF O'FALLON
03-10-06	PER CITY OF O'FALLON
	1
	DATE 01-09-06 1.16.06 02-06-06 02-21-06 03-10-06

ENGINEERS AUTHENTICATION The responsibility for professional engineering liability on this project is hereby limited to the set of plans authenticated by the seal, signature, and date hereunder attached. Responsibility is disclaimed for all other engineering plans involved in this project and specifically excludes revisions after this date unless

reguthenticated. PICKETT, RAY & SILVER, INC J. BARTCH NUMBER E-17751

DRAWN B.PARKS 12-05-05 CHECKED DATE D.BYRD 12-05-05

PROJECT # 01267.BRST.00C TASK # 2 FIELD BOOK

BRIGHT START IMPROVEMENT PLANS GRADING PLAN

C Copyright 2004 by Pickett, Ray & Silver Inc.