



NOTES:

- ALL DRILLED PIERS SHALL BE 1'-9" DIAMETER MINIMUM UNLESS OTHERWISE NOTED.
- DRILLED PIERS DESIGNATED WITH "B" SHALL HAVE A MINIMUM OF 3' Ø BELL. (SEE DETAIL SHEET S-9)
- ALL REINFORCEMENT BAR LAP SPLICES REQUIRED SHALL BE MADE WITH THE FOLLOWING MINIMUM LENGTHS
 

BAR SIZE	LAP LENGTH (INCHES)
#8	60
#7	45
#6	33
#5	26
#4	20
- EACH INTERSECTION OF GRADE BEAMS SHALL BE TIED TOGETHER WITH A MINIMUM STEEL OF THE LESSER BEAM.
- GRADE BEAMS SHALL BE TYPE "D" UNLESS OTHERWISE NOTED.
- SLAB ON GRADE SHALL BE 5" CONCRETE WITH WWF 6x6-W1.4xW1.4 OVER 4" BASE WITH VAPOR BARRIER.

**FOUNDATION PLAN - SOUTH WING**  
SCALE: 1/8" = 1'-0"



Revisions

Project No.	96036
Date	SEPT. 4, 1997
Designed	SEA
Drawn	GBS
Drawing No.	<b>S-1</b>

CONSTRUCTION ISSUE  
DECEMBER 5, 1997

**CONSTRUCTION DOCUMENTS**