



FOUNDATION PLAN - SOUTH WING
SCALE: 1/8" = 1'-0"

- NOTES:**
- ALL REINFORCEMENT BAR LAP SPLICES REQUIRED SHALL BE MADE WITH THE FOLLOWING MINIMUM LENGTHS
- | BAR SIZE | LAP LENGTH (INCHES) |
|----------|---------------------|
| #8 | 60 |
| #7 | 45 |
| #6 | 33 |
| #5 | 26 |
| #4 | 20 |
- SLAB ON GRADE SHALL BE 5" CONCRETE WITH WWF 6x6-W1.4xW1.4 OVER 4" BASE WITH VAPOR BARRIER.
 - THE FOLLOWING CONCRETE COVER SHALL BE PROVIDED FOR REINFORCEMENT
 - A. BOTTOM OF FOOTINGS & WELLS 3"
 - B. SIDES & TOP 2"

Revisions

CONSTRUCTION ISSUE	DECEMBER 5, 1997
CHANGE ORDER NO. 1	JANUARY 27, 1998

Project No.	96036
Date	SEPT. 4, 1997
Designed	SEA
Drawn	GBS
Drawing No.	S-1