



FIRST FLOOR FIRE PROTECTION PLAN - WEST WING AND CENTRAL LOBBY

SCALE: 1/8" = 1'-0"

GENERAL NOTES:

1. PROVIDE A WET PIPE AUTOMATIC SPRINKLER SYSTEM INSTALLED IN COMPLIANCE WITH THE LATEST APPLICABLE EDITION OF NFPA 13.
2. FINAL SPRINKLER HEAD SELECTION AND LOCATION IS THE RESPONSIBILITY OF THE SPRINKLER CONTRACTOR AND SHALL BE IN ACCORDANCE WITH NFPA 13 AND THE MANUFACTURERS LISTING.
3. COORDINATE FINAL LOCATION OF SPRINKLER HEADS WITH LIGHTS, DIFFUSERS, GRILLE, ETC.
4. PROVIDE A WET STANDPIPE SYSTEM IN EACH STRIRWELL INSTALLED IN ACCORDANCE WITH THE LATEST EDITION OF NFPA 14 AND THE 1996 BOCA NATIONAL BUILDING CODE.

KEYED NOTES

- 1 STANDPIPE RISER. PROVIDE OUTLETS AS REQUIRED BY CODES AND LOCAL FIRE DISTRICT.
- 2 COMBINATION STANDPIPE AND AUTOMATIC SYSTEM RISER. PROVIDE OUTLETS AS REQUIRED BY CODE AND LOCAL FIRE DISTRICT.
- 3 PROVIDE INDICATING CONTROL VALVE AND TAMPER SWITCH FOR FEED MAIN SUPPLYING FIRST FLOOR.
- 4 6" BULK MIAN FOR WEST WING. RUN ABOVE CORRIDOR AND LOBBY CEILING.



Revisions

CONSTRUCTION ISSUE
DECEMBER 5, 1997
CHANGE ORDER NO. 1
JANUARY 27, 1998

Project No.	96036
Date	SEPT. 4, 1997
Designed	
Drawn	
Drawing No.	