



**SECOND FLOOR FIRE PROTECTION - SOUTH WING**

SCALE: 1/8" = 1'-0"

**KEYED NOTES**

- 1 POINT OF CONNECTION FOR FEED MAIN TO EAST LOBBY SPRINKLERS.
- 2 PROVIDE TWO (2) HEADS IN STORAGE ROOM AND TWO (2) HEADS FOR FIRST FLOOR AREA BENEATH STORAGE ROOM.

**GENERAL NOTES:**

- 1. PROVIDE A WET PIPE AUTOMATIC SPRINKLER SYSTEM INSTALLED IN COMPLIANCE WITH THE LATEST APPLICABLE EDITION OF NFPA 13.
- 2. FINAL SPRINKLER HEAD SELECTION AND LOCATION IS THE RESPONSIBILITY OF THE SPRINKLER CONTRACTOR AND SHALL BE IN ACCORDANCE WITH NFPA 13 AND THE MANUFACTURERS LISTING.
- 3. COORDINATE FINAL LOCATION OF SPRINKLER HEADS WITH LIGHTS, DIFFUSERS, GRILLE, ETC.

Revisions

CONSTRUCTION ISSUE  
DECEMBER 5, 1997  
CHANGE ORDER NO. 1  
JANUARY 27, 1998

Project No. 96036  
Date SEPT. 4, 1997  
Designed  
Drawn  
Drawing No.