




HVAC SECOND FLOOR PLAN - WEST WING
 SCALE: 1/8" = 1'-0"

KEYED NOTES (THIS SHEET ONLY)

- ① HOLD HEAT PUMP AS HIGH AS POSSIBLE (TYP.). SEE SECTION THRU CORRIDOR.
- ② HOLD FRESH AIR DUCT AS HIGH AS POSSIBLE. SEE SECTION THRU CORRIDOR.
- ③ DUCTWORK ABOVE CEILING (TYP.).
- ④ 14x12 RETURN AIR OPENING IN PARTITION ABOVE CEILING.
- ⑤ RETURN AIR SOUND TRAP ABOVE CEILING (TYP.).
- ⑥ THIS AREA IS USED AS A RETURN AIR PLENUM. SEAL AIR TIGHT ALL AROUND.
- ⑦ SUPPLY AND RETURN DUCT TO HP-2-8. SEE SHEET H-9 FOR CONTINUATION.
- ⑧ THERMA-FUSER. SEE AIR DEVICE SCHEDULE.
- ⑨ 8" DUCT TO THIRD FLOOR. SEE THIRD FLOOR PLAN.
- ⑩ 2" CONDENSATE DRAIN SHALL BE TERMINATED TO MOP SINK IN JANITORS CLOSET.
- ⑪ 3" CWS AND CWR PIPING IN NEAREST WALL.



Revisions
CONSTRUCTION ISSUE DECEMBER 5, 1997

Project No.	96036
Date	SEPT. 4, 1997
Designed	
Drawn	
Drawing No.	H-3