



KEYED NOTES (This sheet only)

- ① UNIT IN ATTIC SPACE IN DRYWALL ENCLOSURE. PROVIDE 8x6 100 CFM SUPPLY AND RETURN GRILLES DUCTWORK TO HEAT AND COOL ENCLOSURE (TYP.)
- ② HR-2 ON ROOF. PROVIDE ROOF CURB.
- ③ 24x24 SUPPLY AND RETURN DUCT DOWN FROM ROOF. INSULATE WITH 2" EXTERNAL FIBERGLASS INSULATION AND WEATHER PROTECTION JACKET.
- ④ DUCTWORK IN ATTIC. PROVIDE 2" EXTERNAL FIBERGLASS INSULATION WITH WEATHER PROTECTED JACKET.
- ⑤ FRESH AIR AND EXHAUST DUCT SHALL BE EXTERNALLY INSULATED WITH 2" FIBERGLASS WRAP INSULATION AND WEATHER PROTECTED JACKET.
- ⑥ CWR AND CWS IN ATTIC SPACE SHOULD BE INSULATED WITH 1 1/2" FIBER GLASS INSULATION AND WEAATHER PROTECTION JACKET.
- ⑦ PROVIDE INSULATION AND CHEMELEX 5XTMCT HEAT TRACE TO CWR, CWS AND ALL NECESSARY EQUIPMENT AND THERMOSTAT CONTROL.



HVAC SECOND FLOOR POWER PLAN - SOUTH WING

SCALE: 1/8" = 1'-0"

Revisions

CONSTRUCTION ISSUE
DECEMBER 5, 1997
CHANGE ORDER NO. 1
JANUARY 27, 1998

Project No. 96036
Date SEPT. 4, 1997
Designed
Drawn
Drawing No.