



CENTRAL LOBBY POWER 3RD FLOOR, S. WING, E. AND W. ENTRY ROOF PLAN

SCALE: 1/8" = 1'-0"

GENERAL NOTES:

1. FOR ACTUAL LOCATIONS REFER TO ARCHITECTURAL AND MECHANICAL DRAWINGS.
2. UNLESS NOTED OTHERWISE ELECTRICAL CONDUCTORS SHALL BE #12 IN 3/4" CONDUIT.
3. USE PANDUIT "PAN-WAY" RACEWAY OR EQUAL WHERE NECESSARY TO CONNECT DEVICES ON EXPOSED MASONRY WALLS.
4. PROVIDE AN ISOLATED GROUND RECEPTACLE IN EACH OFFICE AREA RUN ADDITIONAL INSULATED GROUND FOR THESE CIRCUIT AND CONNECT TO ISOLATED GROUND BUS AT PANEL. VERIFY EXACT LOCATION OF RECEPTACLES WITH OWNER.

KEYED NOTES

- 1 60A 3 HP DISCONNECT SWITCH.
- 2 CONDUCTOR SHALL BE THHN COPPER FOR: SMU-1 AND SEF-1 CONDUCTOR SHALL BE: 3-#6; 1-#8 (GROUND) IN 1" CONDUIT. FOR: SEF-2 CONDUCTOR SHALL BE: 3-#8; 1-#10 (GROUND) IN 1" CONDUIT.
- 3 FOR CONDUCTOR SEE PANEL SCHEDULE CONDUIT SHALL BE 3/4".



138 South Main Street
O'Fallon, Missouri 63366

City of O'Fallon

NEW CITY HALL COMPLEX

**CENTRAL LOBBY ROOF
PLAN**

CONSTRUCTION DOCUMENTS

Revisions

CONSTRUCTION ISSUE
DECEMBER 5, 1997

CHANGE ORDER NO. 1
JANUARY 27, 1998

Project No. 96036
Date SEPT. 4, 1997
Designed
Drawn
Drawing No. **E-15**

CONSTRUCTION DOCUMENTS