



**FIRST FLOOR FIRE ALARM PLAN - SOUTH WING,  
WEST + EAST ENTRANCES, AND CENTRAL LOBBY**  
SCALE: 1/8" = 1'-0"

**GENERAL NOTES:**

1. INSTALL AND LOCATE DEVICES IN ACCORDANCE WITH THE 1996 BOCA NATIONAL BUILDING CODE, NFPA 72 AND NFPA 70.
2. WHERE POWER BOOSTER ARE REQUIRED, CONNECT TO NEAREST 120V/1 CIRCUIT FOR POWER.
3. REFER TO ELECTRICAL AND ARCHITECTURAL DRAWING FOR LOCATION OF DOOR HOLDERS AS WELL AS DOOR LOCK RELEASES.
4. SECURITY CAMERAS TO BE WIRED BACK TO MONITOR IN COMMUNICATION ROOM 2ND FLOOR EAST WING CAMERAS #11 through #20 SHALL BE ON SEPARATE MONITOR.

Revisions

CONSTRUCTION ISSUE	DECEMBER 5, 1997
CHANGE ORDER NO. 1	JANUARY 27, 1998

Project No.	96036
Date	SEPT. 4, 1997
Designed	
Drawn	
Drawing No.	FA-10