



PRINCIPLES & STANDARDS:

1. All excavations, grading, or filling shall have a finished grade not to exceed 3.1 ft (35%) Steeper grades may be approved by the designated official if the excavation is through rock or the excavation or the fill is adequately protected (a designed head wall or toe wall may be required). Retaining walls that exceed a height of four (4) feet shall require the construction of safety guards as identified in the appropriate section(s) of the adopted BOCA Codes and must be approved by the Building Department. Permanent safety guards will be constructed in accordance with the appropriate section(s) of the adopted BOCA Codes.

2. Sediment and erosion control plans for sites that exceed 20,000 square feet of grading shall provide for sediment or debris basins, silt traps or filters, staked straw bales or other approved measures to remove sediment from run-off waters. The design to be approved by the Designated Official. Temporary siltation control measures shall be maintained until vegetative cover is established at a sufficient density to provide erosion control on the site.

3. Where natural vegetation is removed during grading, vegetation shall be reestablished in such a density as to prevent erosion. Permanent type grasses shall be established as soon as possible during the next seeding period after grading has been completed.

4. When grading operations are completed or suspended for more than 30 days permanent grass must be established at sufficient density to provide erosion control on the site. Between permanent grass seeding periods, temporary cover shall be provided according to the City Engineer's recommendations. All finished grades (areas not to be disturbed by future improvement) in excess of 20% slopes (5:1) shall be mulched and tacked at the rate of 100 pounds per 1,000 square feet when seeded.

5. Provisions shall be made to accommodate the increased runoff caused by changed soils and surface conditions during and after grading. Unvegetated open channels shall be designed so that gradients result in velocities of 2 feet per second or less. Open channels with velocities more than 2 fps and less than 5 fps shall be established in permanent vegetation by use of commercial erosion control blankets or lined with rock rip rap or concrete or other suitable materials as approved by the City Engineer. Detention basins, diversions, or other appropriate structures shall be constructed to prevent velocities above 5 fps.

6. The adjoining ground to development sites (lots) shall be provided with protection from accelerated and increased surface water, silt from erosion, and any other consequence of erosion. Run-off water from developed areas (parking lots, paved sites and buildings) above the area to be developed shall be directed to diversions, detention basins, concrete gutters and/or underground outlet systems. Sufficiently anchored straw bales may be temporarily substituted with the approval of the City Engineer.

7. Development along natural watercourses shall have residential lot lines, commercial or industrial improvements, parking areas or driveways set back a minimum of 25 feet from the toe of the existing stream bank. The watercourse shall be maintained and made the responsibility of the subdivision trustees or in the case of a site plan by the property owner. Permanent vegetation should be left intact. Variances will include designed stream bank erosion control measures and shall be approved by the City Engineer, FEMA and U.S. Army Corps of Engineers guidelines shall be followed where applicable regarding site development areas designated as flood plains and wetlands.

8. All lots shall be seeded and mulched at the minimum rates defined in Appendix A or sooner before an occupancy permit shall be issued except that a temporary occupancy permit may be issued by the Building Department in cases of undue hardship because of unfavorable ground conditions.

VEGETATIVE ESTABLISHMENT
For Urban Development Sites
APPENDIX A

Seed/Rates:

Permanent:
Tall Fescue - 30 lbs./ac.
Smooth Brome - 20 lbs./ac.
Crested Wreath - 15 lbs./ac. and Brome @ 10 lbs./ac.

Temporary:
Wheat or Rye - 150 lbs./ac. (3.5 lbs. per square foot)
Oats - 120 lbs./ac. (2.75 lbs. per square foot)

Seedling Periods:
Fescue or Brome - March 1 to June 1
August 1 to October 1
Wheat or Rye - March 15 to November 1
Oats - March 15 to September 15

Mulch Rates:
100 lbs. per 1,000 sq. feet (4,356 lbs. per acre)


Fertilizer Rates:
Nitrogen - 30 lbs./ac.
Phosphate - 30 lbs./ac.
Potassium - 30 lbs./ac.
Lime - 600 lbs./ac. ENM*

* ENM = effective neutralizing material as per State evaluation of quarry rock.

The developer shall comply with current Tree Preservation Ordinance Number 1689 and provide landscaping as set forth in Article 23 of the City of O'Fallon zoning ordinances.

20% of existing trees or 15 trees per acre shall remain whichever is greater.

20% of Existing Tree Masses = 0.02 Ac.
Existing Tree Masses = 0.11 Ac.
Existing Tree Mass to Remain = 0.02 Ac.
No proposed trees needed to meet requirement.



LANDSCAPING AS DEPICTED IS SUBJECT TO FINAL
DESIGN BY A QUALIFIED LANDSCAPE DESIGNER

**A SET OF CONSTRUCTION PLANS FOR
COOL SPRINGS CENTER
A TRACT OF LAND IN FRACTIONAL SECTION 21,
TOWNSHIP 47 NORTH, RANGE 3 EAST OF THE FIFTH PRINCIPAL MERIDIAN
ST. CHARLES COUNTY, MISSOURI**

O'FALLON NOTES (CONTINUED)

- Underground utilities have been plotted from available information and therefore their locations shall be considered approximate only. The verification of the location of all underground utilities, either shown or not shown on these plans shall be the responsibility of the contractor, and shall be located prior to any grading or construction of the improvements.
- All filled places under proposed storm and sanitary sewer, proposed roads, and/or paved areas shall be compacted to 90% of the maximum density as determined by the Modified AASHTO T-150 Compaction Test, or 95% of maximum density as determined by the standard Proctor Test AASHTO T-99. All tests shall be verified by a soils engineer concurrent with grading and backfilling operations. All filled places in proposed roads shall be compacted from the bottom up. All test shall be verified by a soils engineer concurrent with grading and backfilling operations. The moisture content of the soil in the fill areas is with grading and backfilling operations. The moisture content of the soil in the fill areas is with grading and backfilling operations. The moisture content of the soil in the fill areas is with grading and backfilling operations. The moisture content of the soil in the fill areas is with grading and backfilling operations.
- All erosion control systems shall be inspected and necessary corrections shall be made within 24 hours of any rainstorm resulting in one-half inch of rain or more.
- All graded areas that are to remain bare for over 2 weeks shall be seeded and mulched per DNR requirements.
- Rip-rap shown at flared ends will be evaluated in the field after installation for effectiveness and field modified if necessary to reduce erosion on and off-site.
- Marking to be provided on storm sewer inlets. The City will allow the following markers and adhesive procedures only as shown in the table below: "Peel and Stick" adhesive pads will not be allowed.
- No area shall be cleared without the permission of the Project Engineer.
- The City of O'Fallon shall be notified 48 hours prior to construction for coordination and inspection.
- All existing site improvements disturbed, damaged or destroyed shall be repaired or replaced to closely match pre-construction conditions.
- All construction and materials shall conform to the current construction standards of the City of O'Fallon.
- Any permits, licenses, assessments, or approvals required to work on public or private properties or roadways are the responsibility of the developer.
- No slopes shall exceed 3(Horizontal) : 1(Vertical).
- The Contractor shall assume complete responsibility for controlling all siltation and erosion of the project area. The Contractor shall use whatever means necessary to control erosion and siltation including, but not limited to, staked straw bales and/or siltation fabric fences (possible methods of control are detailed in the plan). Control shall commence with grading and be maintained throughout the project until acceptance of the work by the Owner and/or the City of O'Fallon and/or MODOT. The Contractor's responsibilities include all design and implementation as required to prevent erosion and siltation. The Contractor shall be responsible for the design and implementation of all erosion control measures. The Contractor shall be responsible for the design and implementation of all erosion control measures. The Contractor shall be responsible for the design and implementation of all erosion control measures.
- Erosion control systems shall not be limited to what is shown on the plan. Whatever means necessary shall be taken to prevent siltation and erosion from entering natural streams and adjacent roadways, streets and ditches.
- All building mounted lights shall be pointed downward and fully screened to prevent light from spilling over onto adjacent properties.
- All rooftop mechanical units are shown screened by parapet wall and ground mounted units screened with materials and/or landscaping.
- The Developer must supply City Construction Inspectors with soil reports prior to or during site soil testing.
- All paving to be in accordance with St. Charles County standards and specifications except as modified by the City of O'Fallon ordinances.
- All sidewalks, curb ramps, and accessible parking spaces shall be constructed in accordance with the current approved "Americans with Disabilities Act Accessibility Guidelines" (ADAAG) along with the required grades, construction materials, specifications and signage. If any conflict occurs between the above information and the plans, the ADAAG guidelines shall take precedence and the contractor prior to any construction shall notify the Project Engineer. Ensure at least one 5' wide handicap access aisle is provided and curb ramps do not project into handicap access aisles.
- Brick shall not be used in the construction of storm or sanitary sewer structures.
- The Contractor shall ensure all storm and sanitary sewer joint shall be gasketed O-Ring Type.
- Lighting values will be reviewed on the site prior to the final occupancy inspection. Corrections will need to be made if not in compliance with City standards.
- All proposed fencing requires a separate permit through the Planning Division.
- All sign locations and sizes must be approved separately through the Planning Division.

GRADING QUANTITIES:

| |
|--|
| 722 C.Y. FILL (INCLUDES 15% SHRINKAGE) |
| 502 C.Y. CUT (INCLUDES SUBGRADES) |
| 220 C.Y. LIGHT |

THE ABOVE GRADING QUANTITY IS APPROXIMATE ONLY. NOT FOR BIDDING PURPOSES. CONTRACTOR SHALL VERIFY QUANTITIES PRIOR TO CONSTRUCTION.

U.S.G.S. BENCHMARK

REFERENCE BENCHMARK (USGS):
RMS8 ELEV. 456.02
CHISELED SQUARE ON TOP OF THE WINGWALL IN THE NORTHWEST CORNER OF OLD HIGHWAY 79 BRIDGE OVER BELLEAU CREEK.
SITE BENCHMARK: ELEV. 492.99
FOUND OLD STONE OT. IN THE NORTHWEST CORNER OF LOT 7 OF "COOL SPRINGS INDUSTRIAL PARK".



CALL BEFORE YOU DIG!
1-800-DIG-RITE

GRADING NOTES:

- A Geotechnical Engineer shall be employed by the owner and be on site during grading operations. All soils tests shall be verified by the Geotechnical Engineer concurrent with the grading and back filling operations.
- The grading contractor shall perform a complete grading and compaction operation as shown on the plans, stated in these notes, or reasonably implied therefrom, all in accordance with the plans and notes as interpreted by the Geotechnical Engineer.
- The Contractor shall notify the Soils Engineer at least two days in advance of the start of the grading operation.
- All areas shall be allowed to drain. All low points shall be provided with temporary ditches.
- A sediment control plan that includes monitored and maintained sediment control basins and/or straw bales should be implemented as soon as possible. No graded area is to be allowed to remain bare over the winter without being seeded and mulched. Care should be exercised to prevent soil from damaging adjacent property and silt up existing downstream storm drainage system.
- Any existing trash and debris currently on this property must be removed and disposed of off-site.
- Soft soil in the bottom and banks of any existing or former pond sites or tributaries should be removed, spread out and permitted to dry sufficiently to be used as fill. None of this material should be placed in proposed right-of-way locations or on storm sewer locations.
- Site preparation includes the clearance of all stumps, trees, bushes, shrubs, and weeds; the grubbing and removal of roots and other surface obstructions from the site; and the demolition and removal of any man-made structures. The unsuitable material shall be properly disposed of off-site. Topsoil and grass in the fill areas shall be thoroughly discing prior to the placement of any fill. The Soils Engineer shall approve the discing operation.
- Compaction equipment shall consist of tamping rollers, pneumatic-tired rollers, vibratory roller, or high speed impact type drum rollers acceptable to the Soils Engineer. The roller shall be designed so as to avoid the creation of a layered fill without proper blending of successive fill layers.
- The Soils Engineer shall observe and test the placement of the fill to verify that specifications are met. A series of fill density tests will be determined on each lift of fill. Interim reports showing fill quality will be made to the Owner at regular intervals.
- The Soils Engineer shall notify the Contractor of rejection of a lift of fill or portion thereof. The Contractor shall rework the rejected portion of fill and obtain notification from the Soils Engineer of its acceptance prior to the placement of additional fill.
- All areas to receive fill shall be scarified to a depth of not less than 6 inches and then compacted in accordance with the specifications given below. Natural slopes steeper than 1 vertical to 5 horizontal to receive fill shall have horizontal benches cut into the slopes before the placement of any fill. The width and height to be determined by the Soils Engineer. The fill shall be loosely placed in horizontal layers not exceeding 8 inches in thickness and compacted in accordance with the specifications given below. The Soils Engineer shall be responsible for determining the acceptability of soils placed. Any unacceptable soils placed shall be removed at the Contractor's expense.
- The surface of the fill shall be finished so that it will not impound water. If at the end of a day's work it would appear that there may be rain prior to the next working day, the surface shall be finished smooth. If the surface has been finished smooth for any reason, it shall be scarified before proceeding with the placement of succeeding lifts. Fill shall not be placed on frozen ground, nor shall filling operations continue when the temperature is such as to permit the layer under placement to freeze.
- All siltation control devices shall be inspected by the contractor after any rain of 1/2" or more with any appreciable accumulation of mud to be removed and siltation measures repaired where necessary.
- No slope shall be steeper than 3(Horizontal):1(Vertical). All slopes shall be seeded or mulched.
- Any contaminated soil encountered during excavation shall be hauled and placed as directed by the owners environmental engineering representative.
- The location of and details for all siltation control devices (silt fences and sediment basins) must follow the "St. Charles County Soil and Water Conservation District Erosion and Sediment Control" guidelines.
- Phase II Storm water guidelines require that this site provide long term post-construction BMP's such as; low impact design, source controls and treatment controls that protect water quality and control run off to the maximum extent practical.
- Grades for entrances should not exceed 2% at walks, 4% from street, and 10% overall. Typically 2% from back of curb through the right of way is desired.

CITY OF O'FALLON
COMMUNITY DEVELOPMENT DEPARTMENT
ACCEPTED FOR CONSTRUCTION
BY: [Signature] DATE: 10-3-07
PROFESSIONAL ENGINEER'S SEAL
INDICATES RESPONSIBILITY FOR DESIGN

SHEET INDEX

| | |
|---------|------------------------|
| SHEET 1 | COVER SHEET |
| SHEET 2 | SITE PLAN |
| SHEET 3 | GRADING PLAN |
| SHEET 4 | PRE-DRAINAGE AREA MAP |
| SHEET 5 | POST-DRAINAGE AREA MAP |
| SHEET 6 | PROFILES |
| SHEET 7 | CONSTRUCTION DETAILS |
| SHEET 8 | CONSTRUCTION DETAILS |

STANDARD SYMBOLS & ABBREVIATIONS

| | |
|--------------------------|--|
| TREE OR BUSH | |
| LIGHT POLE | |
| SANITARY SEWER & MANHOLE | |
| STORM SEWER & INLET | |
| MAILBOX | |
| ELECTRIC LINE | |
| GAS LINE | |
| WATER LINE | |
| TELEPHONE LINE | |
| CABLE TV LINE | |
| OVERHEAD WIRE | |
| UTILITY POLE | |
| UTILITY POLE W/ DOWN GUY | |
| FIRE HYDRANT | |
| WATER VALVE | |
| WATER METER | |
| GAS VALVE | |
| ROAD SIGN | |
| TELEPHONE PEDESTAL | |
| FENCE | |

DEVELOPMENT NOTES

- Area of Tract: 2.84 Acres
1.39 Acre lot to be developed
- Existing Zoning: I-1 Light Industrial (City of O'Fallon)
- Current Use: Agriculture
- The proposed height and lot setbacks are as follows:
Minimum Front Yard: 30 feet
Minimum Side Yard: 20 feet
Minimum Rear Yard: 35 feet
- Owner of property: Cool Springs Center, LLC
221 Spencer Road, Suite Q
St. Peters, MO 63376
636-696-0825
- Site is served by:
City of O'Fallon Water: 636-272-6818
American Company: 1-800-55-ASKUE
Cadele Gas Company: 636-946-0352
City of O'Fallon Sewer: 636-272-6818
Verizon/Century Telephone Company: 636-332-7318
O'Fallon Fire Department: 636-272-5493
City of O'Fallon: 636-240-2000

RECEIVED
SEP 27 7

- NOTE: The City of O'Fallon shall be contacted for utilities located under it's maintenance area responsibility.
- According to the flood insurance rate map of the City of O'Fallon, Missouri, Flood Insurance Policy Number 290316 0227, dated August 2, 1995 this property is within Zone A and within Zone X. Zone A is defined as areas within the 100 year flood plain, in which base flood level have not been determined. Zone X is defined as an area outside the 500 year flood plain.
 - Flood plain information has been updated per LOMR Document dated 08/07/1998.
 - Site information is per Box Engineering.
 - Boundary information is per Box Engineering.
 - All utilities must be located underground.
 - Paving Calculations:
Office: 1 space per 300 s.f. of floor area.
3,760 / 300 = 12.53
Warehouse: 1 space per employee + 1 space per 1,000 s.f. floor area
5 employees + 2,000/1,000 = 3 + 2 = 5
12.53 + 5 = 17.53 = 18 spaces required
18 spaces provided including 2 handicap spaces
 - The developer will comply with current Tree Preservation Ordinance Number 1689 and provide landscaping as set forth in Article 23 of the City of O'Fallon Zoning Ordinances.
 - Where property abuts a residential zoned property, a 30' wide buffer yard shall be provided. For every 100' of frontage, a total of 3 plant units and a sight-trip, 6' high white vinyl, or other fence as approved by the Planning and Zoning Commission shall be provided. Variance granted January 11, 2006.
 - Landscaping Calculations:
Free per 40 feet of street frontage.
16.58 / 40 = 17.46
Street trees required existing:
Less than 6% of the interior of the parking lot shall be landscaped.
18 spaces x 270 sq. ft. = 4,860 sq. ft. x 6% = 291.60 sq. ft. required
Interior landscaping provided = 889.39 sq. ft.
 - Site Coverage:
Site = 60,549 s.f.
Building = 5,695 s.f. 9% coverage
Pavement = 23,521 s.f. 39% coverage
Greenpace = 31,232 s.f. 52% coverage
 - Retention is provided off-site to the south.
 - Developer will keep all public roadways used to access this site clear of dirt, rock, sediment and other debris during all grading operations.
 - Rip-rap shown at flared ends will be evaluated in the field after installation for effectiveness and field modified as necessary to reduce erosion on and off site.
 - All joints shall be gasketed O-ring type.
 - Brick shall not be used as in the construction of sanitary or storm sewer structures.
 - Traffic control is to be per MODOT or MUTCD whichever is more stringent.
 - All trash for site to be domestic. No dumpster proposed.
 - Variance has been provided to eliminate all landscape buffers. January 11, 2006.
 - Entrance shown off of Cool Springs Industrial Drive will be the only entrance allowed for Lot 1.
 - All siltation control to be per St. Charles County Soil and Water Conservation District Erosion and Sediment Control Guidelines.
 - The estimated daily sanitary flow calculated for both Lots 1 & 2 will be 46,166 gpd.
 - City water meters are placed in a dedicated easement.
 - All sanitary laterals and sanitary mains crossing under pavement must have the proper backfill and to required compaction.
 - Tree Preservation:
Existing tree mass = 4,625.96 sq. ft.
Proposed tree mass = 1,046.39 sq. ft.
1,046.39 / 4,625.96 = 0.226 = 23% tree mass proposed
20% tree mass required

DISCLAIMER OF RESPONSIBILITY
I hereby certify that the documents intended to be authorized by my seal are limited to this sheet. I do not assume any responsibility for all other drawings, specifications, estimates, reports or other documents or instruments relating to or intended to be used for any part or parts of the architectural or engineering project or survey.



REVISIONS

| NO. | DATE | PER CITY COMMENTS |
|-----|------|-------------------|
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |

ENGINEERING PLANNING SURVEYING
221 Point West Blvd.
St. Charles, MO 63301
636-928-8552
FAX 928-1718

07/17/07
DATE
04-13117A1
PROJECT NUMBER
1 OF 8
SHEET OF
13117A1.con.dwg
FILE NAME
JMM
DRAWN
CAL KTK
DESIGNED CHECKED
P. 2 #1105.04 APPROVED 6-21-07

Const. Inspector
Contractor