



Luminaire Schedule					
Symbol	Qty	Label	Description	LLF	Lum. Watts
	11	B-EX	BLED24N	0.950	23
	5	S1-NEW	RSX3 LED P4 40K R3	0.950	311.9213
	9	S1-EX	RSX3 LED P4 40K R3	0.950	311.9213
	1	S1-G-EX	RSX3 LED P4 40K R3 EGS	0.950	311.9213
	3	S2-EX	RSX3 LED P4 40K R5	0.950	311.9213
	1	S3-NEW	RSX3 LED P4 40K R4	0.950	311.9213
	2	S3-EX	RSX3 LED P4 40K R4	0.950	311.9213
	4	WM1-NEW	RSX1 LED P4 40K R3 WBA	0.950	133.1431
	4	WM1-EX	RSX1 LED P4 40K R3 WBA	0.950	133.1431
	4	WM1-RE	RSX1 LED P4 40K R3 WBA	0.950	133.1431
	5	WM2-NEW	RSX1 LED P4 40K R4 WBA	0.950	133.1431
	8	WM2-EX	RSX1 LED P4 40K R4 WBA	0.950	133.1431

Calculation Summary						
Label	Avg	Max	Min	Avg/Min	Max/Min	Units
Site	0.51	16.5	0.0	N.A.	N.A.	Fc
Around Building	2.04	4.9	0.0	N.A.	N.A.	Fc
Parking Lot	2.74	14.3	0.3	9.13	47.67	Fc

These calculations are for estimation or informational purposes only. Actual light levels may vary due to reflectance, temperature, obstructions and other factors. HOLT ELECTRICAL SUPPLIES will not be held responsible for light levels that differ from what is shown on this or any layout provided. Consult with a professional engineer if a more detailed study is needed.

- Lighting Notes**
- FIXTURE HEIGHT SHOWN
  - LABEL NOTES  
EX - EXISTING FIXTURES  
RE - RELOCATING FIXTURES  
NEW - NEW FIXTURES
  - CALCS EVERY 15'
  - FOOT CANDLE VALUES CALCULATED USING .95 LLF

#	Date	Comments

Drawn By: JMB  
Date: 5/19/2021

**Point West Properties**  
601 Pearl Drive  
O'fallon, MO 63376