



**NOTE:** AT ALL SEWER CROSSINGS, HDPE PIPE MUST BE CONCRETE ENCASED.

**NOTE:** IF CONTRACTOR/DEVELOPER USES ALTERNATIVE HDPE PIPE, ALL SEWER CROSSINGS SHALL BE CONCRETE ENCASED. ALL FLARED END SECTIONS AND INLET STRUCTURES WILL BE CONCRETE.

**SCALE:**  
 VERTICAL = 1:10  
 HORIZONTAL = 1:50