



**NOTE:** AT ALL SEWER CROSSINGS, HDPE PIPE MUST BE CONCRETE ENCASED.

**NOTE:**  
 IF CONTRACTOR/DEVELOPER USES ALTERNATIVE HDPE PIPE,  
 ALL SEWER CROSSINGS SHALL BE CONCRETE ENCASED.  
 ALL FLARED END SECTIONS AND INLET STRUCTURES WILL BE CONCRETE.

**SCALE:**  
 VERTICAL = 1:10  
 HORIZONTAL = 1:50

E:\proj\970901\proj\970901\storm.dwg, Tue Apr 24 08:56:05 2001, JMK