

- <u>GENERAL NOTES:</u> 1. Existing sanitary sewer service shall not be interrupted.
- Connection to Duckett Creek Sanitary District (DCSD) sanitary sewer requires DCSD inspection. Contact DCSD Chief Inspector, Mr. Steve Overby, at 636-441-1244 to schedule inspection. 24-hour notice is required.

DUCKETT CREEK SANITARY DISTRICT ABAONDONMENT NOTES:

- DUCKETT CREEK SANTTART DISTRICT ABAONDONMENT NOTES:
 Duckett Creek Sanitary Sewer District (DCSD) inspection, coordination, and approval is required for reolignment or abandonment of existing sanitary sewer main.
 Existing sanitary sewer service shall not be interrupted.
 Existing sanitary sewer main shall not be abandoned until replacement system is installed, inspected and approved by DCSD Field Inspector.
 Recorded easementation is required for replacement sewer prior to abandonment of minimum.

- 4. Recorded easementation is required for replacement sewer prior to aborderment or existing sanitary sewer.
 5. Sewer to be abandoned shall be filled with grout and securely blocked at ony points of intake and discharge with a bulkhead or pre-formed plug as required by DCSD. Filling and plugging activities shall be witnessed by a DCSD Field Inspector. The Contractor will be allowed to remove that portion of sewer to be abandoned in lieu of filling and blocking.

| Copyright 2008 Clayton Engineering Co. All Rights Reserved | The signed and sealed original of this drawing The Clayton Engineering Company, Inc. The the official document and shall take preceder | signed and sealed original is |
|--|---|--|
| | BID SET REVISIONS | |
| | UTILITY PLA | AN |
| | SKILLED CARE EX Highway N and Twin Chimneys Boulevard Propared for: DELMAR GARDENS ENTI 14805 N. Outer Chesterfield, MO 636-733-70 | <u>O'Falion, Missouri 63366</u> ERPRISES, INC. r 40 63017 |
| MICHAEL JAMES VELLOFF NUMBER E-2000161862 | the clayton engineering company, inc. ENGINEERS • SURVEYORS • PLANNERS 11920 WESTLINE INDUSTRIAL DRIVE ST. LOUIS, MISSOURI 63146 (314) 692-8888 FAX: (314) 592-8688 clayton-engineering.com | Designed RKF Drawn RKF Checked MJV Data 01/29/08 Project Number 00228.11 Sheet Number 10 C-5 of PLOTIED: 92/14/08_09:38 BY: 108F |