


DRI-PORT MARINE IMPROVEMENT PLANS

CITY OF O'FALLON GENERAL NOTES

- Gas, water and other underground utilities shall not conflict with the depth or horizontal locations of existing and proposed sanitary and storm sewers, including house laterals.
- Underground utilities have been plotted from available information and, therefore, their locations must be considered approximate only. The verification of the location of all underground utilities, either shown or not shown on these plans, shall be the responsibility of the contractor and shall be located prior to grading or construction of improvements.
- Polyvinyl Chloride (PVC) shall conform to the requirements of ASTM D-3034 Standard Specifications for the PSM Polyvinyl Chloride (PVC) Sewer Pipe and Fittings, SDR-35.
- Storm sewers 18" in diameter or smaller shall be ASTM C-14.
- Storm sewers 21" in diameter or larger shall be ASTM C-76, Class II.
- All storm sewer pipe under pavement, regardless of size, shall be reinforced concrete pipe (ASTM C-76, Class III) unless noted otherwise in the plans.
- Corrugated metal pipe shall conform to the standard specifications for corrugated culvert pipe M-36, A.A.S.H.T.O. See plans for gauge.
- All filled places under buildings, proposed sanitary and storm sewer lines, and/or paved areas including trench backfills shall be compacted to 90% of maximum density as determined by the Modified A.A.S.H.T.O. T-180 Compaction Test (ASTM D-1557) unless otherwise specified by the local governing authority specifications. All tests will be verified by a soils engineer.
- All earthen filled places within State, County, or City roads (Highways) shall be compacted to 95% of maximum density as determined by the Standard Proctor Test A.A.S.H.T.O. T-99 (ASTM D-698) unless otherwise specified by local governing authority specifications. All tests will be verified by a soils engineer.
- All storm and sanitary trench backfills shall be water jetted. Granular fill will be used under paved areas.
- Easements shall be provided for storm sewers, sanitary sewers, and all utilities on the record plat. See record plat for location and size of easements. This does not apply to house laterals.
- No area shall be cleared without the permission of the developer.
- All grades shall be within 0.2 feet (more or less) of those shown on the grading plan.
- No slope shall be greater than 3:1 and shall be either sodded or seeded and mulched.
- Hazard markers will consist of three (3) standard specification, "Manual on Uniform Traffic Control Devices," and of roadway markers mounted on two (2) pound "U" channel sign post. Each marker shall consist of an eighteen (18) inch diamond reflectorized red panel. The bottom of each panel shall be mounted a minimum of four (4) feet above the elevation of the pavement surface.
- All manhole and curb inlet tops built without elevations furnished by the Engineer will be the responsibility of the sewer contractor. At the time of construction stake-out of the sewer lines, all curb and grate inlets will be face staked. If normal face stakes fall in line with sewer construction, the Engineer will set these stakes on a double offset. It shall be the responsibility of the sewer contractor to preserve all face stakes from destruction.
- All standard street curb inlets to have front of inlet 2 feet behind curb.
- The minimum vertical distance from the low point of the basement to the flowing of a sanitary sewer at the corresponding house connection shall not be less than the diameter of the sanitary sewer plus a vertical distance not less than two and one-half feet (2-1/2').
- Water lines, valves, sleeves, meters and etc., shall meet all specifications and installation requirements of the local governing authority.
- All cast iron pipe for water mains shall conform to A.W.W.A. specification C-106 and/or C-108. The cast iron fittings shall conform to A.W.W.A. specification C-110. All rubber gasket joints for water cast iron pressure pipe and fittings shall conform to A.W.W.A. specification C-111.
- All water hydrants and valves shall be cast iron and installed in accordance with plans and details.
- All sanitary and storm sewers shall meet all specifications and installation requirements of the local governing authority.
- All PVC water pipe shall have a minimum pressure rating of PR-200 or SDR-21.
- All PVC sanitary sewer pipe shall be DR-35 or equal with crushed stone bedding uniformly graded between 1" and 1/4" size. This bedding shall extend from 6" below the pipe to 12" above the top of the pipe.
- All grading on Missouri State Highway Right-of-Way shall be seeded and mulched and all disturbed Right-of-Way markers shall be reset at the completion of grading.
- All streets must meet the specifications and installation requirements of the City of O'Fallon.
- All sanitary manholes top shall be set 0.2' higher than the proposed ground except in pavement areas.
- All sanitary manholes shall have a 31 mill thick coat of coal tar pitch waterproofing.
- All sanitary service lines shall have a 6" diameter for Multi-family and a 4" diameter for single-family developments.
- Manhole frame and cover shall be Clay and Bailey No. 2008 or Neenan R-1736 or Deeter 1315 or approved equal.
- A drop of 0.2 feet is required through each sanitary manhole.
- The City of O'Fallon shall be notified at least 48 hours prior to construction of sanitary sewers for coordination and inspection.
- Brick shall not be used on manholes.
- Sewer contractor shall maintain 24" vertical separation between all storm sewers and the sludge force main. Contractor shall be responsible for verifying separation prior to storm sewer installation.
- Waterproofing: Waterproofing will be required on the exterior of all manholes. The bitumen shall consist of two coats of asphalt, coal-tar pitch, or a coating meeting American Society for Testing and Materials (ASTM) D-41. Asphalt shall conform to the requirements of ASTM D-449. Coal-tar pitch shall conform to the requirements of ASTM D-450. Coating shall be 31 mil thickness.
- NOTE: The grading and elevations shown on the grading plans are for construction purposes only. Finished grades and slopes will vary from those shown on the plans depending upon the location, size and type of house built on the lot. However, care should be taken to insure that finished grading conforms to drainage area maps.
- Per F.I.R.M. #2918300220 E, August 2, 1996, site is located outside the 500-year floodplain.
- Developer must supply City construction inspectors with soil reports prior to or during site soil testing.
- The contractor shall assume complete responsibility for controlling all siltation and erosion on the project area. The contractor shall use whatever means necessary to control erosion and siltation including, but not limited to, staked straw bales and/or siltation fabric fences (possible methods of control are detailed in the plan). Control shall commence with grading and be maintained throughout the project until acceptance of the work by the Owner and/or the City of O'Fallon and/or MoDOT. The contractor's responsibilities include all design and implementation as required to prevent erosion and the depositing of silt. The Owner and/or the City of O'Fallon and/or MoDOT may at their option direct the Contractor in its methods as deemed fit to protect property and improvements. Any depositing of silts or mud on new or existing pavement or in new or existing storm sewers or swales shall be removed after each rain and affected areas cleaned to the satisfaction of the Owner and/or the City of O'Fallon and/or MoDOT.

LOCATION MAP



DRAWING INDEX

Sheet	Description
1	COVER SHEET
2	SITE PLAN
3	GRADING PLAN
4	LIGHTING PLAN
5	LANDSCAPING PLAN
6	DRAINAGE AREA MAP
7	SILTATION PLAN
8	DETAIL + PROFILE SHEET
9	DETAIL SHEET
10	ENTRANCE DETAIL

LEGEND

18	Lot or Building Number	(MA)	Manhole	R.C.P.	Reinforced Concrete Pipe
- - -	Existing Fence Line	(CA)	Curb Structure	C.M.P.	Corrugated Metal Pipe
(T)	Existing Tree Line	(C.I.P.)	Cast Iron Pole	C.I.P.	Cast Iron Pipe
(S)	Street Sign	(P.V.C.)	Polyvinyl Chloride	P.V.C.	Polyvinyl Chloride
- - -	Existing Contour	(V.C.P.)	Vitrified Clay Pipe	V.C.P.	Vitrified Clay Pipe
- - -	Proposed Contour	(C.O.)	Clean Out	C.O.	Clean Out
(G.R.)	Grouted Rip-Rap	(V.T.)	Vent Trap	V.T.	Vent Trap
(E.L.)	End of Lateral	(T.B.R.)	To Be Removed	T.B.R.	To Be Removed
(A.P.)	Asphalt Pavement	(T.B.R.&R)	To Be Removed & Relocated	T.B.R.&R	To Be Removed & Relocated
(C.P.)	Concrete Pavement	(T.B.P.)	To Be Protected	T.B.P.	To Be Protected
(S.S.P.)	Sanitary Sewer (Proposed)	(T.B.A.)	To Be Abandoned	T.B.A.	To Be Abandoned
(S.S.E.)	Sanitary Sewer (Existing)	(B.C.)	Base Of Curb	B.C.	Base Of Curb
(S.S.P.)	Storm Sewer (Proposed)	(T.C.)	Top Of Curb	T.C.	Top Of Curb
(S.S.E.)	Storm Sewer (Existing)	(T.W.)	Top Of Wall	T.W.	Top Of Wall
(W.L.)	Water Line & Size	(B.W.)	Base Of Wall	B.W.	Base Of Wall
(E.W.)	Existing water line	(TYP)	Typical	(TYP)	Typical
(T&V)	Tee & Valve	(U.N.O.)	Unless Noted Otherwise	U.N.O.	Unless Noted Otherwise
(H)	Hydrant	(U.I.P.)	Use Pipe	U.I.P.	Use Pipe
(C)	Cap				

BENCHMARKS

TBM 1: Top railroad rail near northwest corner of this site
ELEVATION = 504.35

TBM 2: Top Iron Pipe with cap at the southeast corner
of this site.
ELEVATION = 565.65

RECEIVED

OCT 15 2006

CITY OF O'FALLON, MO

10-16-02 gtb
APPROVED

NOT APPROVED FOR CONSTRUCTION

PICKETT RAY & SILVER

Civil Engineers
Planners
Land Surveyors

333 Mid Rivers Mall Dr.
St. Peters, MO 63376
397-1211 FAX 397-1104

CITY FILE # 19900

PICKETT RAY & SILVER
CIVIL ENGINEERS
PLANNERS
LAND SURVEYORS

333 Mid Rivers Mall Drive
St. Peters, MO 63376
Phone (636) 397-1211
Fax (636) 397-1104

DRI-PORT MARINE
COVER SHEET
O'FALLON, MISSOURI

Prepared For:
MR. GREG MAZE

REVISIONS	NO.	DATE	DESCRIPTION
	1	06.19.02	PER CITY'S COMMENTS
	2	08.23.02	PER CITY'S COMMENTS
	3	10.09.02	PER CITY'S COMMENTS
	4	10.11.02	PER CITY'S COMMENTS

ENGINEERS AUTHENTICATION
The responsibility for professional engineering liability on this project is hereby limited to the set of plans authenticated by the seal, signature, and date hereunder attached. Responsibility is disclaimed for all other engineering plans involved in this project and specifically excludes revisions after this date unless reauthenticated.

PICKETT, RAY & SILVER, INC.
HAROLD J. BARTCH
REGISTERED PROFESSIONAL ENGINEER
NO. 117751

SCANNED
JUN 24 2016

DRAWN	DATE
J.M.W.	02.25.02
CHECKED	DATE
D.W.B.	02.25.02

PROJECT # 00214.DRP0.02C
TASK # 1 FIELD BOOK

DRI-PORT MARINE
COVER SHEET

SHEET 1 OF 10

© Copyright 2002 by Pickett, Ray & Silver Inc.