

VEGETATION ESTABLISHMENT For Urban Development Sites
APPENDIX A



SEEDING RATES:
PERMANENT:
Tall Fescue - 30 lbs./ac.
Smooth Brome - 20 lbs./ac.
Combined - Fescue @ 15 lbs./ac. AND Brome @ 10 lbs./ac.
TEMPORARY:
Wheat or Rye - 150 lbs./ac. (3.5 lbs. per sq. ft.)
Oats - 120 lbs./ac. (2.75 lbs. per sq. ft.)

SEEDING PERIODS:
Fescue or Brome - March 1 to June 1
August 1 to October 1
Wheat or Rye - March 15 to November 1
Oats - March 15 to September 15

MULCH RATES:
100 lbs. per 1000 sq. ft. (4,356 lbs. per ac.)

FERTILIZER RATES:
Nitrogen 30 lbs./ac.
Phosphate 30 lbs./ac.
Potassium 30 lbs./ac.
Lime 600 lbs./ac. ENM*

* ENM = effective neutralizing material as per State evaluation of quarried rock.



GENERAL NOTES:

- USE A 24" CMP PERFORATED RISER PIPE FOR 24 HOUR DEWATERING. 28 - 1" HOLES ARE REQUIRED IN 3 EVENLY SPACED COLUMNS AND 10 ROWS. THE SPACING BETWEEN ROWS IS A MINIMUM OF 2 1/2". THE TOP ELEVATION OF THE PIPE IS 593.1' AND THE LOWEST ELEVATION OF DEWATERING HOLES IS 589.7'
- STANDPIPES SHALL BE WRAPPED WITH FILTER FABRIC (MIRAFI 140 NL OR EQUAL) AND SECURELY FASTENED.
- TRASH RACK SHALL BE MADE FROM #4 BARS @ 6" SPACING BOTH WAYS AND FASTENED TO TOP OF STANDPIPE.

REMARKS/DATE

1	FIRST SUBMITTAL - 6-10-06
2	09-22-06 REVISED PER ST. CHARLES CO. COMMENTS
3	10-24-06 REVISED PER CITY OF FALLON COMMENTS
4	06-25-07 SUBMITTED FOR APPROVAL

PREPARED FOR:
CROSS DEVELOPMENT OF MISSOURI, INC.
1609 PROSPECT VILLAGE DR.
LAKE ST. LOUIS, MO. 63367
314-713-4054



PREPARED BY:
THE STERLING CO.
ENGINEERS & SURVEYORS
3805 NEW BALDWIN ROAD
ST. LOUIS, MISSOURI 63120
(314) 487-0440 FAX 487-4944
E-Mail: Sterling@sterling-eng-sur.com

PROJECT: **THE ENCLAVE AT SOMMERS POINTE**

DRAWN: [] DESIGNED: [] CHECKED: []

SHEET TITLE: **SILTATION CONTROL DETAILS**

NO.	06	04	087
M.S.D.			
P#			
SHEET			8
OF			

Drawing name: K:\V664537_P010111_L0011\Fed\Grading\408736999.DWG Plotfile: g:\globe\... Jul 06, 2007 - 4:17pm Printed by: glocbe