



All utilities shall be underground.

All buried utility trenches shall be backfilled with rock.

Back flow prevention devices shall be located within the appropriate building(s).

All sanitary and gutter drain cleanouts shall have an adjustable metal cap with an H2O loading capacity.

FN2004.04145 - Fastlane O'Fallon SITE PLAN rev 9-22-2004 134437 AM EST