



- 1. 3500 PSI MIN. 28 DAY COMPRESSIVE STRENGTH CONCRETE WITH GRADE 60 REINFORCING STEEL. IF WATER IS PRESENT IN HOLE, REMOVE BEFORE POURING CONCRETE.
2. FOUNDATION EXCAVATION SHALL BE BY 24" AUGER IN UNDISTURBED OR PROPERLY COMPACTED FILL PER SPECIFICATIONS.
3. FOUNDATION SHALL HAVE A MINIMUM ALLOWABLE END BEARING OF 2000 PSF.
4. FOUNDATION HAS BEEN DESIGNED FOR A GRANULAR SOIL BASED ON A MINIMUM COHESIVE VALUE OF 1000 PSF.
5. FOUNDATION HAS BEEN DESIGNED FOR A GRANULAR SOIL BASED ON A MINIMUM LATERAL SOIL PRESSURE OF 1000 PSF, UTILIZING AASHTO FIGURE 1.8.2c(4) OF "EMBEDMENT OF POSTS WITH OVERTURNING LOADS".
6. EXPOSED CONCRETE SHALL BE PAINTED TRAFFIC YELLOW. ALL LIGHT POLE BASE FOUNDATIONS SHALL BE CAST-IN-PLACE. PRE-CAST LIGHT POLE BASE FOUNDATIONS ARE NOT ACCEPTABLE.
7. POLE AND FIXTURE SHALL BE BLACK IN COLOR.

