

VERT. 1" = 10'  
 1" = 50'  
 HORIZ. SCALE:

All sanitary lateral street crossings, if trenched, shall be backfilled with granular material (aggregate).

Storm sewer pipes that cross over existing or proposed sanitary sewer trenches shall be cradled in concrete through the full width of the sanitary sewer trench. The trench shall be backfilled and compacted with granular fill to the bottom of the concrete cradle.


If the storm and sanitary sewer are parallel and in the same trench or overdig, the upper pipe shall be placed on a shelf and the lower pipe shall be bedded in compacted granular fill to the flow line of the upper pipe.

Rock backfill all storm and sanitary sewers that lie within the 1:1 shear plane of the road.

01/16/04	REVISED AS PER COMMENTS
02/19/04	REVISED AS PER COMMENTS
02/26/04	REVISED AS PER COMMENTS

**SANITARY PROFILES  
 HIDDEN CREEK  
 PHASE 2**

ST. CHARLES ENGINEERING & SURVEYING, INC.  
 801 S. FIFTH STREET, SUITE 202  
 ST. CHARLES, MO 63301  
 TEL: (636) 947-0607 FAX: (636) 947-9448



ORDER NO.	02-0162-01
DATE	12/15/03
PH2-10	