



- SANITARY NOTES:
1. A minimum of 6" diameter pipe shall be used for sanitary laterals.
 2. A minimum of 8" diameter pipe shall be used for sanitary sewers.
 3. Sewer grease traps and cleanouts required on sanitary laterals as shown.
 4. Inside drop manholes must be a minimum of 48" in diameter.
 5. Sanitary sewer line placement shall be a minimum of 10' from any proposed structures.
 6. All manholes are to have a minimum 0.20' drop across the structure.
 7. For drop structures, compacted rock backfill is required in the disturbed ground around the structure.
 8. A concrete cradle for RCP and encasement for HOPE will be required for all storm sewer lines when crossing less than 18" above the sanitary lines.

**SANITARY PROFILE
 KING ARTHUR'S
 HIGHLAND TERRACE
 IMPROVEMENT PLANS**

12/24/07 revised per City comments
 1/29/08 revised per City comments

S | C | S
S | E | S
 ST. CHARLES ENGINEERING & SURVEYING, INC.
 801 S. FIFTH STREET, SUITE 202
 ST. CHARLES, MO 63301
 TEL: (636) 947-0607 FAX: (636) 947-2448

[Signature]
 1-30-08

ORDER NO.
 07-0059-01
 DATE
 07/03/07