



04/16/04 Revised as per City Comments
 07/23/04 Revised as per MNR Comments
 11/10/04 Revised SAN LOT 150

Revised 11-17-09 RJS

MAGNOLIA SANITARY PROFILE

ST. CHARLES ENGINEERING & SURVEYING, INC.
 801 S. FIFTH STREET, SUITE 202
 ST. CHARLES, MO 63301
 TEL: (636) 947-0607 FAX: (636) 947-2448

S E S

STATE OF MISSOURI
 PROFESSIONAL ENGINEER
 11-10-04

ORDER NO. 030498
 DATE 1-26-04
 24

All sanitary lateral street crossings, if trenched, shall be backfilled with granular material (aggregate).

Storm sewer pipes that cross over existing or proposed sanitary sewer trenches shall be croaded in concrete through the full width of the sanitary sewer trench. The trench shall be backfilled and compacted with granular fill to the bottom of the concrete cradle.

If the storm and sanitary sewer are parallel and in the same trench or overdig, the upper pipe shall be placed on a shelf and the lower pipe shall be bedded in compacted granular fill to the flow line of the upper pipe.

All storm sewer and sanitary sewer within the 1:1 shear plane of the proposed roads shall be granular backfilled.

CONTRACTOR TO FIELD VERIFY FL OF EXISTING SANITARY SEWER PRIOR TO CONNECTION

DATUM ELEV	575.00
607.8	
609.2	
608.3	
607.1	
608.31	
604.1	
602.8	
601.5	

