



DRY BUILDING 53

Numeric Summary							
Label	CalcType	Units	Avg	Max	Min	Avg/Min	Max/Min
PARKING	Illuminance	Fc	1.95	13.7	0.0	N.A.	N.A.
SPILL	Illuminance	Fc	0.13	0.7	0.0	N.A.	N.A.

Luminaire Schedule						
Symbol	Qty	Label	Arrangement	Lumens	LLF	Description
SA	5	SA	SINGLE	14000	0.729	MHI-17
SB	1	SB	SINGLE	36000	0.729	CAL-400-MH-XX-SLE

TYPIC SB CALCULATED AT 25 FOOT ABOVE FINISHED GRADE

1 PHOTOMETRIC PLAN
PH 1/PH SCALE: NOT TO SCALE

COPYRIGHT © 2007 LEPIQUE & ORNE ARCHITECTS, INC.

LePIQUE & ORNE ARCHITECTS, INC.
ESTABLISHED 1916
701 N. FIFTH STREET, SAINT CHARLES, MO 63301
PHONE (636) 947-0089 FAX (636) 947-8700

NEW BUILDING ADDITION FOR:
BRAMKO
832 MIDPOINT DR.
O'FALLON, MISSOURI 63366
GENERAL CONTRACTOR: BILL DAVIS

ISSUE	DATE

PROJECT MANAGER
DRAWN BY: GML
PROJECT NUMBER
07-113
DATE
OCTOBER 2, 2007

SHEET
PH-1
PHOTOMETRIC PLAN