

NOTES:
All MH Tops set at 0.2' above prop. grade.
Use only compacted, crushed clean limestone for backfill over pipe.
MH exteriors shall be waterproofed with a minimum of 31 mils. of coal tar pitch or approved equal.

FINAL SURVEY
DRAWING
PLATE
NO. 82-120
DATE
BY
AREAS CHECKED

ORIGINAL SURVEY
DRAWING
PLATE
NO. 82-120
DATE
BY
AREAS CHECKED

