

Austin
Carrollton
Denver
New York
St. Louis
319 North 4th Street
Suite 1000
St. Louis, MO 63102

phone 314-533-0100
fax 314-533-0100

Project Team:
General Contractor: PARC, 1801 Boardwalk Springs Pl., D'Fallon, MO 63366
Civil Engineer: Pickett Ray & Silver, Inc., 223 Mid Rivers Mall Drive, St. Peters, MO 63376
Structural Engineer: ABS Consulting, 1844 Lockland Hill Pkwy., St. Louis, MO 63146
Mechanical Designer: Jorrell Mechanical, 4208 Rider Trail North, Earth City, MO 63045
Plumbing Designer/Contractor: Kuhl Plumbing, 13168 Taunung Avenue, Bridgeton, MO 63044
Electrical Designer/Contractor: Crown Electrical, 3630 South Broadway, St. Louis, MO 63118



Professional Seal
Project Title:

O'Fallon, Missouri 63366

Park Place
Independent and Assisted Living Apartments
Phoenix Parkway (Village M)

This drawing and details on it are the sole property of the architect and may be used for this specific project only. It shall not be copied, reprinted, reproduced, in whole or in part, or for any other purpose or project without the written consent of the architect.

No.	Revision Description	Date
1	CITY OF O'FALLON, DCSO	1-07-05

BUILDING PERMIT SET

Sheet Title:

DCSC DETAILS 3

Project Number: 04188
Sheet Number: **C13**

Drawn By: C.V.C.
Issue Date: NOV. 15, 2004

FILE# 9831.51

SDR-35 x C900 BELL x BELL ADAPTERS

SIZE	CATALOG NO.	A	B	C	D	E	F	G	H	CT	PT
4"	334-040	4.56	8.23	4.25	4.10	3.94	4.80	2.72	2.7	.32	.25
6"	334-060	6.66	9.93	6.31	4.57	5.88	6.90	3.72	3.5	.45	.36

DUCKETT CREEK SANITARY DISTRICT
SDR-35 x C900 BELL AND SPIGOT ADAPTERS
Des: BSM, App: KLA, Date: 1-3-01, Detail No: 19A

SDR-35 x C900 BELL x SPIGOT ADAPTERS

SIZE	CATALOG NO.	A	L	STYLE
4"	335-040	3.2	10.0	FABRICATED
6"	335-060	2.9	3.5	HARCO
8"	335-080	4.0	12.5	FABRICATED

DUCKETT CREEK SANITARY DISTRICT
SDR-35 x C900 BELL AND SPIGOT SPECIAL 4", 6" & 8" ADAPTERS
Des: BSM, App: KLA, Date: 1-3-01, Detail No: 19B

SDR-35 x C900 BELL x BELL ADAPTERS

SIZE	CATALOG NO.	OD	ID	OD C900 SEWER	ID C900 SEWER	L	CTN	WT
4x4	337-040	4.80	4.215	4.86	4.25	10.0	1	4
6x6	337-060	6.90	6.275	6.96	6.32	11.13	1	8
8x8	337-080	9.05	8.400	9.13	8.45	12.50	1	15

DUCKETT CREEK SANITARY DISTRICT
SDR-35 x C900 BELL AND BELL 4", 6" & 8" ADAPTERS
Des: BSM, App: KLA, Date: 1-3-01, Detail No: 19C

PLASTIC SADDLE TEE OR WYE FITTING (SOLVENT WELD)

EXISTING PLASTIC PIPE
ADJUSTABLE STAINLESS STEEL STRAPS AND SCREWS

WHEN CONNECTION TO A PLASTIC PIPE IS ALLOWED AND A CONNECTION IS LARGER THAN 6" IN DIAMETER, A SOLVENT WELD WYE OR TEE FITTING OF A SIMILAR MATERIAL MUST BE USED. (EXAMPLE: 10" x 8")

THIS IS ACCOMPLISHED BY CAREFULLY CUTTING A HOLE WITH A SAW IN THE MAIN AT THE REQUIRED LOCATION AFTER CUTTING AND SHAPING THE HOLE TO THE SIZE OF THE FITTING. THE FOLLOWING STEPS SHOULD BE TAKEN:

- CLEAN AND DRY BOTH INSIDE THE SADDLE WYE SURFACE AND PIPE SURFACE TO BE SOLVENT CEMENTED.
- IMPORTANT: APPLY A LIBERAL HEAVY COAT OF ONE-STEP SOLVENT CEMENT TO THE INSIDE SURFACE OF THE SADDLE WYE AND TO THE EXTERIOR WELDING SURFACE TO THE PIPE.
- WITHOUT DELAY, MATE THE SURFACES AND STRAP DOWN TIGHTLY. A BEAD OF SOLVENT SHOULD APPEAR AFTER THE SADDLE HAS BEEN STRAPPED DOWN TIGHTLY.
- USING A RAG OR PAPER TOWEL, WIPE BEAD AND ANY EXCESS SOLVENT CEMENT OFF PIPE AND SADDLE.
- ALLOW 30-60 MINUTES FOR SET-UP TIME BEFORE BACKFILLING. CURE TIME DEPENDS ON SIZE FIT OF MATERIALS BEING INSTALLED AND VARIOUS COLD DAMP CONDITIONS.
- DISCARD OLD SOLVENT IF IT BECOME JELLED OR LUMPY.
- A CLEAN, DRY BEDDING MATERIAL IS REQUIRED AROUND THE COMPLETED CONNECTION BEFORE BACKFILLING. THE BEDDING MATERIAL SHOULD BE ONE OF THE FOLLOWING:
 - 1 TO 3 CEMENT TO SAND MIX
 - "PRE-MIX" CONCRETE
 - DCSD APPROVED BEDDING FOR SANITARY SEWERS.

DUCKETT CREEK SANITARY DISTRICT
8" & LARGER CONNECTION TO PLASTIC MAIN
Des: BSM, App: KLA, Date: 1-4-01, Detail No: 20A

INSERTA TEE
THE USE OF AN INSERTA TEE REQUIRES DISTRICT APPROVAL.

INSTALLATION PROCEDURE:

- CORE THE PROPER SIZE HOLE. TEE SIZE: 4" 6" 8" 10" 12" 15". BIT SIZE: 4 1/2" 6 1/2" 8 1/2" 10 1/2" 12 1/2" 15 1/2"
- INSERT THE RUBBER SLEEVE (1) IN THE CORED HOLE WITH THE GOLD VERTICAL LINE ON THE RUBBER SLEEVE (2) FACING TO THE SIDE OF THE MAIN LINE. THE UPPER SEGMENT SHOULD BE ON TOP OF THE WALL OR TOP AND THE LOWER SEGMENT (PVC, PROFILE WALL, AND POLYETHYLENE PIPE ONLY) SHOULD BE ON THE INSIDE OF THE PIPE.
- APPLY THE INSERTA TEE SOLUTION SUPPLIED TO THE INSIDE OF THE RUBBER SLEEVE AND TO THE OUTSIDE OF THE PVC HUB ADAPTER. CAUTION - DO NOT USE AN OIL BASED LUBRICANT.
- PLACE THE PVC HUB ADAPTER (3) INTO THE RUBBER SLEEVE. MAKE SURE THAT THE RED VERTICAL LINE (4) ON THE PVC HUB ADAPTER IS IN LINE WITH THE GOLD VERTICAL LINE (2) ON THE RUBBER SLEEVE.
- PLACE THE 2x4 BOARD ONTO THE TOP OF THE PVC HUB ADAPTER.
- THE RED HORIZONTAL LINE (5) AT THE TOP OF THE HUB ADAPTER IS A DEPTH MARK. THIS TELLS THE INSTALLER HOW FAR TO DRIVE THE ADAPTER INTO THE RUBBER SLEEVE. DRIVE THE PVC HUB ADAPTER INTO THE RUBBER SLEEVE TO WHERE THE HORIZONTAL RED LINE (5) ON THE PVC HUB ADAPTER (3) MEETS THE TOP OF THE RUBBER SLEEVE (1).
- PLACE THE STAINLESS STEEL BAND (7) AROUND THE TOP OF THE RUBBER SLEEVE AND TIGHTEN DOWN.
- INSTALL PIPE IN NORMAL MANNER.

DUCKETT CREEK SANITARY DISTRICT
INSERTA TEE DETAILS AND SPECIFICATIONS
Des: BSM, App: KLA, Date: 1-4-01, Detail No: 20B

CLASS "A" CONCRETE ENCASEMENT

NOTES:

- WHEN A CONNECTION IS ALLOWED LARGER THAN 6" DIAMETER A SADDLE MAY BE USED IF THE I.D. OF THE CONNECTION PIPE IS NOT GREATER THAN ONE HALF (1/2) OF THE I.D. OF THE MAIN SEWER. (EXAMPLE: 24" x 10")
- IF THE I.D. OF THE CONNECTION PIPE IS GREATER THAN ONE HALF (1/2) OF THE I.D. OF THE MAIN SEWER THE WYE OR TEE MUST BE "ROLLED IN". (EXAMPLE: 15" x 8")
- THIS IS ACCOMPLISHED BY BREAKING AWAY AND REMOVING ONE SECTION OF PIPE. THE TOP HALF OF THE BELL ON THE PIPE LYING ADJACENT TO THE GAP IS CAREFULLY BROKEN OFF. THE TOP HALF OF THE BELL ON THE MAIN REPLACEMENT SECTION (WITH A "TEE" WYE) FITTING IS ALSO BROKEN OFF. THE REPLACEMENT PIPE IS THEN PLACED IN THE LINE GAP WITH THE STUB POINTED IN THE WRONG DIRECTION. THE BROKEN BELLS ON THE REPLACEMENT AND ADJOINING PIPE MAKE IT POSSIBLE FOR THE REPLACEMENT SECTION TO FIT INTO THE SEWER LINE WITHOUT DISTURBING THE ADJOINING PIPE SECTIONS. THE REPLACEMENT SECTION IS THEN ROTATED TO THE DESIRED POSITION AND THE BROKEN BELLS ARE ENCASED WITH A 6" CLASS "A" CONCRETE ENCASEMENT.
- ID OF MAIN SEWER SHALL NOT BE DECREASED BY A ROLL-IN CONNECTION.

DUCKETT CREEK SANITARY DISTRICT
"ROLL-IN" (FOR EXISTING CLAY OR CONCRETE PIPE)
Des: BSM, App: KLA, Date: 1-5-01, Detail No: 21

APPROVED CLOSURES ON 1/8" BEND

CLASS "A" CONCRETE ENCASEMENT 6" MIN.
PIPE TO BE 6" IN DIAMETER
WILL REQUIRE SMOOTH TRANSITION REDUCER AT EACH END IF LINE SIZE IS LESS THAN 6"
ALL PIPE TO BE DUCTILE IRON PIPE

DUCKETT CREEK SANITARY DISTRICT
FORCE MAIN CLEANOUT BORING (6" DIA. & SMALLER)
Des: BSM, App: KLA, Date: 1-5-01, Detail No: 22

BORING DETAIL

NOTES:

- INSIDE DIAMETER OF CASING PIPE TO BE MINIMUM OF 4" GREATER THAN COUPLING DIAMETER OF CARRIER PIPE.
- ENCASEMENTS TO BE INSTALLED UNDER THE ROAD BY MEANS OF JACKING IT THROUGH, OR BY DRY BORING A HOLE THAT WILL RECEIVE THE CASING WITH A SNUG FIT.
- THE OUTSIDE DIAMETER OF THE CASING SHALL NOT BE LESS THAN, NOR MORE THAN ONE INCH GREATER THAN THE BORED HOLE.
- THE ANNULAR SPACE BETWEEN THE CASING PIPE AND THE BORED HOLE SHALL BE FILLED WITH GROUT.

SECTION A-A'

DUCKETT CREEK SANITARY DISTRICT
ROADWAY BORING DETAIL
Des: BSM, App: KLA, Date: 1-5-01, Detail No: 23