



**ADDITIONAL SANITARY SEWER NOTES FOR ST. CHARLES COUNTY**  
 ALL SANITARY LATERAL STREET CROSSINGS, IF TRENCHED, SHALL BE BACKFILLED WITH GRANULAR MATERIAL (AGGREGATE).  
 STORM SEWER PIPES THAT CROSS OVER EXISTING OR PROPOSED SANITARY SEWER TRENCHES SHALL BE CRADLED IN CONCRETE THROUGH THE FULL WIDTH OF THE SANITARY SEWER TRENCH. THE TRENCH SHALL BE BACKFILLED AND COMPACTED WITH GRANULAR FILL TO THE BOTTOM OF THE CONCRETE CRADLE.  
 CONTRACTOR MUST NOTIFY THE OWNERS OF THE PRIVATE PROPERTIES AFFECTED BY THE OFF-SITE SANITARY SEWER CONSTRUCTION A MINIMUM OF 48 HOURS BEFORE COMMENCING THE OFF-SITE IMPROVEMENTS.  
 IF THE STORM AND SANITARY SEWER ARE PARALLEL AND IN THE SAME TRENCH OR OVERDIG, THE UPPER PIPE SHALL BE PLACED ON A SHELF AND THE LOWER PIPE SHALL BE BEDDED IN COMPACTED GRANULAR FILL TO THE FLOW LINE OF THE UPPER PIPE.

VERT. SCALE: 1"=10'  
 HORIZ. SCALE: 1"=60'

REVISIONS:  
 09/25/03 REVISION PER DDC COMMENTS  
 09/25/03 REVISION PER DDC COMMENTS  
 09/26/03 REVISION PER CITY OF JARDINE PARK AND ST. CHARLES COUNTY COMMENTS

**IMPROVEMENT PLANS  
 PEACEFUL VALLEY  
 SANITARY PROFILES 1**

ST. CHARLES ENGINEERING & SURVEYING, INC.  
 801 S. FIFTH STREET, SUITE 202  
 ST. CHARLES, MO 63301  
 TEL: (636) 947-0607 FAX: (636) 947-2448

**S E S**

ORDER NO. 02-0890  
 DATE 07/25/03  
 5