


PIEPERS GLEN

OCTOBER 21, 1998 96-8433A







TYPICAL WATER MAIN INSTALLATION DETAILS

NOT TO SCALE

TYPICAL WATER AND SEWER SEPARATION NOT TO SCALE

WATER MAIN

VERTICAL DISTANCE

SANITARY SEWER MAIN

3' MIN. FROM TOP OF

SANITARY SEWER TO

BOTTOM OF WATER


SANITARY SEWER

WATER MAIN


HORIZONTAL DISTANCE

10' MIN. BETWEEN SANITARY


SEWER AND WATER MAIN




GATE VALVE W/THRUST BLOCK



FLUSHING HYDRANT



FIRE HYDRANT INSTALLATION DETAIL



TYPICAL THRUST BLOCK DETAILS

MAIN SIZE (I.D.)	MIN. THRUST BLOCK BEARING DIMENSIONS TO BEAR AGAINST UNDISTURBED EARTH				
	45° BEND	22 1/2" BEND	TEE	VALVE	CROSS
2"	.5' X 1'	.5' X 1'	.5' X 1'	.5' X 1'	.5' X 1'
4"	1' X 1'	1' X 1'	2' X 1'	2' X 1'	1' X 1'
6"	1.5' X 1'	1' X 1'	2' X 1'	2' X 1'	1' X 1'
8"	2' X 1'	1' X 1'	2' X 2.5'	2' X 2'	1' X 1.5'
10"	2' X 2.5'	1.5' X 2'	2' X 3.5'	2' X 3'	2' X 2'
12"	2' X 3.5'	1.5' X 2.5'	3' X 3.5'	3, X 3,	2' X 3'
16"	3' X 4'	2' X 3'	4' X 4.5'	3' X 4.5'	3' X 3.5'