



- B. Added modular block retaining wall detail.

Item 7: Sheets C7.1, 7.2, 7.3, and 7.4 Storm Sewer Profiles

- A. Manhole 9, 20, and 29 top elevations revised for grading modifications.
- B. Area inlet 28 top/sill lowered for grading modifications.

Item 8: Sheets C8.1, 8.2, 8.3, 8.4, 8.5, and 8.6 Sanitary Sewer Profiles

- A. Building 4 Elevation corrected.
- B. Building 5, 6, 8, and 10 elevation adjusted on profiles for grading modifications.
- C. Manhole 110 and 138 tops adjusted for grading modifications.
- D. Cleanout 114, 115, 116, 117, 119, 120, 121, 123, 134, 135, 136, 140, 141, 143, and 147 top adjusted for grading modifications.
- E. Profile from 126 to 129 revised to avoid conflict with existing light standard. Manholes 127 and 128 moved but total depth remains unchanged.

Item 9: Sheet C9.1 Water Main Profiles

- A. Water profiles updated to avoid existing light standard.