



100 NORTH MAIN STREET  
O'FALLON, MISSOURI 63366  
636.240.2000  
FACSIMILE 636.978.4144  
www.ofallon.mo.us

December 5, 2013

Pyramid Network Services, L.L.C.  
Attn: Lara Gale  
2 City Place Drive, Suite 200  
Creve Couer, MO 63141

Phone: (801) 410-2102

**Project: 1250 T.R. Hughes Boulevard (St. Charles County Cell Tower Site)**  
**Subject: New Entrance Approval**  
**Invoice/Permit Number: 13-0099**

Dear Ms. Gale:


The City of O'Fallon has reviewed and approved the New Entrance for the above mentioned project. The following is a general checklist for this site:

- ✓ Contact the Construction Inspection Group at (636) 379-5596 to schedule a preconstruction meeting with the Construction Inspection Division.
- ✓ Traffic control, following M.U.T.C.D. or MoDOT requirements, shall be in place prior to any pavement removal.
- ✓ The entrance pavement shall match the pavement thickness of T.R Hughes Boulevard and transition to 7" P.C. concrete over a 4" Type 1 or Type 5 aggregate base doweled into T.R Hughes Boulevard with 18" long #5 bars at 12" on center. Concrete shall reach 4,000 p.s.i. at 28 days minimum.
- ✓ The concrete curb on T.R. Hughes Boulevard shall be sawcut to the nearest joint outside the new entrance.
- ✓ All underground utility locates shall be through the Missouri One Call System at 1-800-344-7483.
- ✓ Siltation control is to be erected before construction begins to prevent sediment from entering streets, storm sewers or adjacent properties. Any soil or mud tracked onto any street from the site must be removed immediately.
- ✓ Schedule all inspections through the Construction Inspection Department 24 hours in advance at 636-379-5596. The Invoice/Permit Number will be required when scheduling the inspection.

It is the responsibility of the contractor and/or property owner to obtain all necessary approvals from all other departments and outside organizations as required. All City ordinances, standards and specifications shall be followed during the construction of the entrance. This approval is for compliance with City standards and ordinance requirements and is not a certification of any plans.

If you have any questions, I can be reached at [bcopeland@ofallon.mo.us](mailto:bcopeland@ofallon.mo.us) or (636) 379-5471.

Sincerely,



Robert Copeland  
Plan Reviewer

cc via email: Jay Herigodt – Assistant City Engineer  
Karl Ebert – Senior Construction Inspector  
File through RC