

LIGHT FIXTURE SCHEDULE

TYPE	MANUFACTURER	CATALOG NO.	LAMP		FINISH	MOUNTING	VOLTS	IN FT	APPROVED EQUAL	REMARKS	
			NO.	WATTS							
A	LITHONIA	ZSPG332A12 277 1/3 GEB	3	32	F32TB/ SP41	STD.	RECESSED	277	100	HUBBELL RD3GNA02-B8 DAY-BRITE 2DG332-FS02-277-1/3-EB	
B	LITHONIA	ZSPG232A12 277 GEB	2	32	F32TB/ SP41	STD.	RECESSED	277	65	HUBBELL RD2GNA02-B4 DAY-BRITE 2DG232-FS02-277-1/2-EB	
C	LITHONIA	ZSPG317A12 277 1/3 GEB	3	17	F17TB/ SP41	STD.	RECESSED	277	60		
D	LITHONIA	C232 WG 277 GEB	2	32	F32TB/ SP41	STD.	PENDANT	277	65	HUBBELL SW42R-B4 DAY-BRITE T-232-277-EB	MOUNT BOTTOM OF FIXTURE AT 9'-0" AFF
E	LITHONIA EMERGENCY	ELU4 N	2	12	PAR 36	STD.	SURFACE	277	30	DUAL LITE ML-7E-12V EMERGH-LIGHT 12LSC50-21UE)	
F	LITHONIA	VW332 277 1/3GEB	3	32	F32TB/ SP41	STD.	PENDANT	277	100		MOUNT BOTTOM OF FIXTURE AT 9'-0" AFF
G	LITHONIA	W232 277 GEB	2	32	F32TB/ SP41	STD.	WALL	277	75		
H	MOLDCAST	V-54 120	1	100	A19	STD.	RECESSED	120	100		CONCRETE POUR RATED
J	LITHONIA	ZPM3NGB332 18LD277 1/3GEB	3	32	F32TB/ SP41	STD.	RECESSED	277	100		
K	LITHONIA DOWNLIGHTING	AF 218DTT 6AR 277 GEB	2	18	F18DTT 4100K	STD.	RECESSED	277	45	CAPRI PL18/277 HFF-T442	
L	GOOSENECK	XX XX	1	150	X X	ARCH	WALL	277	150		
M	ACCENT STREET LIGHT	XX XX	1	150	X X	ARCH	POLE	277	150		
⊗	LITHONIA EMERGENCY	LES1R 277 ELN	--	---	---	STD.	WALL OR CEILING	277	5	EMERGH-LITE 12LEDPIR277E1	DIRECTIONAL ARROWS AS INDICATED ON DRAWINGS.
⊗ ²	LITHONIA EMERGENCY	LES2R 277 ELN	--	---	---	STD.	WALL OR CEILING	277	5	EMERGH-LITE 12LEDP2R277E1	DIRECTIONAL ARROWS AS INDICATED ON DRAWINGS.

FIXTURE GENERAL NOTES:

- REFER TO ARCH. DRAWINGS FOR EXACT FIXTURE LOCATIONS.
- FIXTURE TRIM TO BE SUITABLE FOR TYPE OF CEILING INSTALLED. REFER TO ARCH. PLANS.
- ALL INCANDESCENT LAMPS, AS SPECIFIED, ARE ENERGY SAVING EXTEND SERVICE.
- UTILIZE 8 FOOT TANDEM (2-LAMP & BALLAST) IN LIEU OF 2-4 FOOT FIXTURES IN CONTINUOUS ROW INSTALLATIONS WHERE POSSIBLE.
- CONTRACTOR SHALL PROVIDE NECESSARY BALLASTS FOR SWITCHING SHOWN ON DRAWINGS.
- ALL T-8 FLOURESCENT LAMPS SHALL BE RAPID START TYPE UNLESS NOTED OTHERWISE.

Disclaimer of Responsibility

I hereby specify that the documents intended to be authenticated by my seal are limited to drawings and specifications containing my seal with signature and date, and I hereby disclaim any responsibility for all other plans, specifications, estimates, reports or other documents or instruments relating to or intended to be used for any part or parts of the architectural or engineering project or survey.



SPORT

HELLMUTH OBATA & KASSABAUM,
Architecture, Engineering, Planning
Interiors, Facility Programming
323 West 8th Street, Suite 700
Kansas City, Missouri 64105

STRUCTURAL ENGINEER

Kate Conrad Graham Associates
801 Walnut - Suite 301
Kansas City, Missouri 64106

MECHANICAL/ELECTRICAL/PLUMBING

Bendon & Associates
950 61st Street - Suite 214
Raytown, Missouri 64133

CIVIL ENGINEER

George Disher Associates, Inc.
221 South Main Street - Suite 200
O'Fallon, Missouri 63366-2892

T. R. HUGHES BALLPARK
AT THE OZZIE SMITH SPORTS COMPLEX



for the River City Rascals

PACKAGE REVISIONS		
NO.	DATE	DESCRIPTION

PROJECT NO.
97-0761-00
ISSUED BY:
HOK SPO
DRAWN BY:
JLD
REVIEWED BY:
A
ISSUED:
7-7-98
SHEET TITLE

ELECTRICAL SYMBOL
SCHEDULES & DETAILS

CATEGORY - SUB-CATEGORY -

E.1-1