



PRECAST CONCRETE STORMWATER STRUCTURES
 MINIMUM DISTANCE FROM TOP OF STONE OR GRADE

PIPE DIA.	MIN. DIST.	MIN. DIST.	MIN. DIST.	MIN. DIST.
12"	48"	48"	48"	48"
15"	60"	60"	60"	60"
18"	72"	72"	72"	72"
24"	96"	96"	96"	96"
30"	120"	120"	120"	120"
36"	144"	144"	144"	144"
42"	168"	168"	168"	168"
48"	192"	192"	192"	192"
54"	216"	216"	216"	216"
60"	240"	240"	240"	240"
66"	264"	264"	264"	264"
72"	288"	288"	288"	288"
78"	312"	312"	312"	312"
84"	336"	336"	336"	336"
90"	360"	360"	360"	360"

NOTE: #4 OR #5 BARS REQUIRED 2" HIGH REINFORCING SECTION TO 4" DIA. SHALL BE ADAPTED FROM SHEET 31.
 #4 OR #5 BARS REQUIRED 2" HIGH REINFORCING SECTION TO 4" DIA. SHALL BE ADAPTED FROM SHEET 31.

PRECAST CONCRETE STORMWATER STRUCTURES
 METROPOLITAN ST. LOUIS SEWER DISTRICT
 Standard Details of Sewer Construction
 Dr. J.L.C. SEPT. 1990 SHEET 31