

INTERIOR ROOM REFLECTANCE VALUES OF 50-60-25  
 INTERIOR LIGHT LEVEL CALCULATED 2.5' AFF  
 SITE LIGHTING LEVEL CALCULATED ON THE GROUND

Calculation Summary							
Label	CalcType	Units	Avg	Max	Min	Avg/Min	Max/Min
SITE	Illuminance	Fc	3.99	35.4	0.3	13.30	118.00
SPILL LIGHT	Illuminance	Fc	0.08	0.8	0.0	N.A.	N.A.
WAREHOUSE_Workplane	Illuminance	Fc	0.00	0.0	0.0	N.A.	N.A.

Luminaire Schedule							
Symbol	Qty	Label	Arrangement	LLF	Lum. Watts	Total Watts	Description
□	17	F1	Single	0.900	266.89	4537.13	LHB-36-UNV-L850-CD-U
□	1	S1	Single	0.900	131	131	PFPRV1-C40-T4-20-HS
□	28	WP	Single	0.900	69.7	1951.6	WPMLED25S-70W_SWITCH-4000K

DESIGN IS BASED ON CURRENT INFORMATION PROVIDED AT THE TIME OF REQUEST. ANY CHANGES IN MOUNTING HEIGHT OR LOCATION, LAMP WATTAGE, LAMP TYPE, AND EXISTING FIELD CONDITIONS, THAT EFFECT ANY OF THE PREVIOUSLY MENTIONED, WILL VOID CURRENT LAYOUT AND REQUIRE A CHANGE REQUEST AND RECALCULATION.

