

UPP STR	LOW STR	L	DIA	UPPER FL LN	LOWER FL LN	PS	UPPER ST EL	DEPTH HY GR	UPPER HY EL	LOWER HY EL	HYDR GRADE	FR HEAD	VEL	VEL HEAD	JUNC LOSS	TURN LOSS	CURVE LOSS	STR GRADE	INL CAP	DR AREA	PI	Q	TQ	RIPE CAP	REMARKS	
A199	A198	314	12	535.91	528.06	2.50	540.50	4.15	536.35	528.45	.00420	1.31	2.93	0.13	0.17	0.00	0.00	2S	5.50	0.87	2.64	2.30	2.30	5.63	1	
A198	A197	244	15	527.86	522.50	2.20	532.50	4.05	528.45	523.09	.00470	1.14	3.59	0.20	0.18	0.00	0.00	2S	5.50	0.80	2.64	2.11	4.41	9.57	2	
A197	A185	122	18	518.62	517.40	1.00	527.80	6.29	521.51	520.96	.00340	0.41	3.45	0.19	0.06	0.08	0.00	2S	5.50	0.64	2.64	1.69	6.10	10.50	3	
CI102	AI100	135	12	534.03	523.77	7.60	538.75	4.36	534.39	525.30	.00590	0.80	3.49	0.19	0.25	0.00	0.00	LOW	4.00	1.04	2.64	2.74	2.74	9.82	4	
AI101	AI100	105	12	525.86	523.77	2.00	532.50	6.57	525.93	525.30	.00420	0.44	2.95	0.14	0.19	0.00	0.00	3S	8.25	0.88	2.64	2.32	2.32	5.04	5	
AI100	AI88	58	15	523.57	522.40	2.02	528.90	3.60	525.30	523.98	.01050	0.61	5.39	0.45	0.43	0.28	0.00	3S	8.25	0.59	2.64	1.56	6.62	9.17	6	
AI106	AI105	226	12	549.12	540.10	3.99	553.90	4.46	549.44	540.34	.00180	0.42	1.95	0.06	0.08	0.00	0.00	2S	5.50	0.58	2.64	1.53	1.53	7.12	7	
AI105	CI104	95	12	539.90	538.95	0.99	545.30	4.96	540.34	539.28	.00150	0.15	1.78	0.05	-0.01	0.04	0.00	2S	5.50	0.53	2.64	1.40	1.40	3.55	8	
CI104	CI103	49	15	538.75	537.28	3.00	544.57	5.29	539.28	537.63	.00430	0.21	3.46	0.19	0.23	0.03	0.00	2.36%	1.79	0.50	2.64	1.32	4.25	11.19	9	10.52
CI103	AI90	176	15	537.08	529.00	4.59	543.17	5.54	537.63	529.61	.00750	1.32	4.56	0.32	0.23	0.11	0.00	3.69%	1.32	0.51	2.64	1.35	5.60	13.84	10	BYPASS TO AI89
AI96	CI95	107	12	555.08	554.01	1.00	560.30	4.73	555.57	554.34	.00220	0.23	2.11	0.07	0.09	0.00	0.00	3S	8.25	0.63	2.64	1.66	1.66	3.56	11	
CI95	CI94	34	15	553.81	553.47	1.00	560.59	6.25	554.34	553.58	.00140	0.05	2.00	0.06	0.02	0.00	0.00	2.86%	1.61	0.30	2.64	0.79	2.45	6.46	12	
CI94	MH93A	60	12	553.27	552.67	1.00	560.51	6.93	553.58	552.79	.00830	0.50	4.13	0.26	0.29	0.00	0.00	2.96%	1.57	0.30	2.64	0.79	3.24	3.55	13	
MH93A	AI93	93	12	552.47	551.03	17.48	559.30	7.71	552.79	537.32	.00830	0.77	4.13	0.26	0.00	0.00	0.00		0.00	0.00	0.00	0.00	3.24	14.98	14	
AI93	MH92	70	15	535.83	534.99	1.24	542.30	5.18	537.82	535.99	.00970	0.68	5.18	0.42	0.38	0.27	0.00	3S	8.25	1.18	2.64	3.12	6.36	7.08	15	
MH92	AI91	122	15	534.79	533.33	1.20	542.30	6.31	535.99	534.61	.00970	1.16	5.18	0.42	0.00	0.20	0.00		0.00	0.00	0.00	0.00	6.36	7.07	16	
AI91	AI90	129	15	533.13	530.49	2.04	540.00	5.39	534.61	531.46	.01830	2.37	7.12	0.79	0.65	0.13	0.00	3S	8.25	0.90	2.64	2.38	8.74	9.72	17	
AI90	AI89	109	18	528.00	523.85	3.81	537.50	7.89	529.61	525.51	.02340	2.55	9.10	1.29	1.00	0.55	0.00	3S	8.25	0.66	2.64	1.74	16.08	20.50	18	
AI89	AI88	125	24	523.65	522.40	1.00	530.00	4.49	525.51	523.98	.00650	0.82	5.82	0.53	0.71	0.00	0.00	3S	8.25	0.83	2.64	2.19	18.27	22.62	19	FR/ AI103 0.03CFS
AI88	CI87	140	27	522.20	520.11	1.49	528.00	4.02	525.98	521.92	.00770	1.07	6.82	0.72	0.34	0.45	0.00	3S	11.00	0.84	2.64	2.22	27.11	31.54	20	
CI87	CI86	34	27	519.91	518.76	3.30	527.75	5.83	521.92	521.54	.00820	0.28	7.01	0.77	0.10	0.00	0.00	LOW	4.00	0.33	2.64	0.87	27.98	36.76	21	
CI86	AI85	116	30	518.56	517.40	1.00	527.75	6.21	521.54	520.96	.00500	0.59	5.92	0.54	0.00	0.00	0.00	LOW	4.00	0.40	2.64	1.06	29.04	41.32	22	
AI85	FE84	108	30	517.20	515.90	1.20	523.50	2.54	520.96	519.09	.00790	0.85	7.41	0.85	0.52	0.50	0.00	3S	8.25	0.46	2.64	1.21	36.35	45.00	23	
CI74	AI61	162	12	528.80	518.11	6.60	533.15	4.01	529.14	522.00	.00420	0.68	2.93	0.13	0.17	0.00	0.00	LOW	4.00	0.87	2.64	2.30	2.30	9.15	24	
CI76	DC175	35	15	528.52	528.17	1.00	533.37	4.50	528.87	528.31	.00030	0.01	0.90	0.01	0.01	0.00	0.00	2X	1.93	0.42	2.64	1.11	1.11	6.46	25	
DC175	AI61	152	12	527.97	518.11	6.49	533.53	5.22	528.31	522.00	.00420	0.64	2.95	0.14	0.18	0.00	0.00	2X	1.93	0.46	2.64	1.21	2.32	9.07	26	
AI77	AI62	242	12	530.47	528.05	1.00	536.10	4.98	531.42	529.40	.00600	1.46	3.53	0.19	0.25	0.00	0.00	3S	8.25	1.05	2.64	2.77	2.77	3.56	27	
AI79	AI78	189	12	549.89	535.70	7.51	554.50	4.22	550.28	538.38	.00790	1.50	4.04	0.25	0.33	0.00	0.00	2S	5.50	1.20	2.64	3.17	3.17	9.76	28	
AI78	CI66	154	18	535.50	533.96	1.00	541.00	2.62	538.38	536.19	.00940	1.45	5.77	0.52	0.59	0.15	0.00	3S	8.25	2.66	2.64	7.02	10.19	10.50	29	
CI68A	CI68	48	12	537.27	536.79	1.00	541.71	3.91	537.80	537.76	.00040	0.02	0.88	0.01	0.01	0.00	0.00	3.33%	1.46	0.26	2.64	0.69	0.69	3.56	30	
AI83	CI80	86	15	558.00	557.14	1.00	563.00	4.67	558.33	557.83	.00350	0.30	3.12	0.15	0.20	0.00	0.00	2S	5.50	1.45	2.64	3.83	3.83	6.46	31	
CI82	CI81	34	15	557.00	556.66	1.00	561.83	4.53	557.30	556.96	.00010	0.01	0.64	0.01	0.01	0.00	0.00	4X	1.21	0.30	2.64	0.79	0.79	6.46	32	
CI81	CI80	54	15	556.46	555.92	1.00	561.93	5.27	556.66	556.60	.00060	0.03	1.29	0.03	0.03	0.00	0.00	4X	1.21	0.30	2.64	0.79	1.58	6.46	33	
CI80	CI73	45	15	555.72	555.27	1.00	564.10	7.50	556.60	555.85	.00780	0.35	4.64	0.33	0.29	0.11	0.00	6.43%	0.50	0.12	2.64	0.29	5.70	6.46	34	
AI73A	CI73	71	12	557.40	555.27	3.00	562.40	4.64	557.76	555.85	.00220	0.15	2.11	0.07	0.09	0.00	0.00	3S	8.25	0.63	2.64	1.66	1.66	6.17	35	
CI73	CI72	55	18	555.07	554.52	1.00	564.10	8.25	555.85	555.31	.00530	0.29	4.35	0.29	0.04	0.21	0.00	6.43%	0.50	0.11	2.64	0.32	7.68	10.50	36	
CI72	CI71	34	18	554.32	553.91	1.21	561.12	5.81	555.31	554.85	.00640	0.22	4.76	0.35	0.11	0.13	0.00	2.06%	1.90	0.28	2.64	0.74	8.42	11.54	37	
CI71	MH70	55	18	553.71	552.88	1.51	561.02	7.21	553.81	553.19	.00760	0.42	5.18	0.42	0.13	0.07	0.00	2.06%	1.90	0.28	2.64	0.74	9.16	12.90	38	
MH70	AI69	110	18	552.68	539.04	12.40	558.60	5.41	553.19	539.85	.00760	0.84	5.18	0.42	0.00	0.14	0.00		0.00	0.00	0.00	0.00	9.16	36.99	39	
AI69	CI68	102	18	538.84	536.79	2.01	544.60	4.75	539.85	537.76	.01390	1.42	7.01	0.76	0.60	0.07	0.00	3S	8.25	1.22	2.64	3.22	12.38	14.89	40	
CI68	DCI67	44	21	536.59	535.93	1.50	541.83	4.07	537.76	537.16	.00800	0.35	5.91	0.54	-0.09	0.34	0.00	4.39%	1.07	0.43	2.64	1.14	14.21	19.41	41	BYPASS TO CI67
DCI67	CI66	48	21	535.73	535.25	1.00	541.66	4.50	537.16	536.19	.00980	0.47	6.53	0.66	0.23	0.27	0.00	4.26%	3.10	0.57	2.64	1.50	15.71	15.84	42	
CI66	CI65	34	27	533.76	533.42	1.00	540.30	4.11	536.19	535.16	.00780	0.27	6.88	0.73	0.21	0.55	0.00	LOW	4.00	0.55	2.64	1.45	27.35	30.97	43	FR/ CI68-0.07CFS
CI65	MH64	92	27	533.22	532.30	1.00	540.30	5.14	535.16	533.67	.00900	0.83	7.40	0.85	0.23	0.43	0.00	LOW	4.00	0.78	2.64	2.06	29.41	30.97	44	
MH64	AI63	131	27	532.10	530.79	1.00	542.30	8.63	533.67	531.79	.00900	1.18	7.40	0.85	0.00	0.70	0.00		0.00	0.00	0.00	0.00	29.41	30.97	45	
AI63	AI62	169	27	530.59	528.05	1.50	541.60	9.81	531.79	529.40	.00980	1.44	7.73	0.93	0.16	0.57	0.00	3S	8.25	0.50	2.64	1.32	30.73	37.07	46	

A162	MH61A	175	27	527.85	524.36	1.99	533.60	4.20	529.40	525.18	.01460	2.55	9.40	1.37	0.79	0.88	0.00	3S	8.25	1.47	2.64	3.89	37.39	43.74	47	
MH61A	A161	75	27	524.16	518.11	8.07	530.50	5.32	525.18	522.00	.01460	1.09	9.40	1.37	0.00	0.00	0.00		0.00	0.00	0.00	0.00	37.39	87.96	48	
A161	FE60	74	27	516.06	514.00	2.78	523.50	1.50	522.00	519.09	.02130	1.57	11.36	2.00	1.14	0.20	0.00	3S	8.25	1.19	2.64	3.14	45.15	51.67	49	
C159	FES8	151	12	509.57	502.00	5.01	516.26	6.30	509.96	503.00	.00540	0.81	3.32	0.17	0.23	0.00	0.00	LOW	4.00	0.99	2.64	2.61	2.61	7.98	50	FR/ C157-0.08CFS
C157	C156	37	15	518.53	518.16	1.00	523.66	4.80	518.86	518.45	.00020	0.01	0.73	0.01	0.01	0.00	0.00	5.11Z	0.82	0.34	2.64	0.90	0.90	6.46	51	BYPASS TO C159
C156	A155	150	12	517.96	516.46	1.00	522.94	4.49	518.45	516.95	.00230	0.34	2.15	0.07	0.09	0.00	0.00	4.55Z	1.00	0.30	2.64	0.79	1.69	3.56	52	
A155	FES4	145	12	514.26	505.40	6.11	523.90	9.23	514.67	506.40	.00700	1.01	3.79	0.22	0.24	0.04	0.00	2S	5.50	0.49	2.64	1.29	2.98	8.81	53	
A152A	A152	120	12	509.05	507.25	1.50	516.30	5.12	511.18	509.70	.00910	1.09	4.33	0.29	0.39	0.00	0.00	3S	8.25	1.29	2.64	3.40	3.40	4.36	54	
C153	A152	196	12	515.16	507.25	4.04	523.04	7.47	515.57	509.70	.00470	0.91	3.09	0.15	0.20	0.00	0.00	LOW	4.00	0.92	2.64	2.43	2.43	7.16	55	
A152	FES1	55	18	507.05	506.50	1.00	512.20	2.50	509.70	509.32	.00440	0.24	3.94	0.24	0.06	0.08	0.00	3S	8.25	0.43	2.64	1.14	6.97	10.50	56	
C148	FE47	153	12	513.43	505.00	5.51	518.25	4.52	513.73	509.32	.00210	0.32	2.09	0.07	0.09	0.00	0.00	LOW	4.00	0.62	2.64	1.64	1.64	8.36	57	FR/ C137-0.33 BYP
C136	C135	34	15	521.00	520.66	1.00	525.93	4.92	521.01	520.99	.00020	0.01	0.80	0.01	0.01	0.00	0.00	2Z	1.93	0.37	2.64	0.98	0.98	6.46	58	
C135	A124	146	12	516.96	515.50	1.00	525.93	8.47	517.46	515.71	.00260	0.38	2.32	0.08	0.10	0.00	0.00	2Z	1.93	0.32	2.64	0.84	1.82	3.56	59	
C145	C141	34	15	538.00	537.66	1.00	542.94	4.52	538.43	537.76	.00060	0.02	1.29	0.03	0.04	0.00	0.00	3Z	1.57	0.60	2.64	1.58	1.58	6.46	60	BYPASS TO C137
C144	C143	34	15	547.94	547.60	1.00	553.13	4.89	548.24	547.79	.00020	0.01	0.67	0.01	0.01	0.00	0.00	3Z	1.57	0.31	2.64	0.82	0.82	6.46	61	
C143	C142	148	12	547.40	543.24	2.81	553.13	5.34	547.79	543.44	.00280	0.41	2.39	0.09	0.11	0.01	0.00	3Z	1.57	0.40	2.64	1.06	1.88	5.97	62	
C142	C141	199	15	543.04	537.86	2.60	548.94	5.50	543.44	538.26	.00130	0.27	1.93	0.06	0.00	0.00	0.00	3Z	1.57	0.17	2.64	0.49	2.37	10.42	63	
C141	C140	127	12	537.66	533.86	2.99	542.94	5.18	537.76	534.43	.01980	2.51	6.38	0.63	0.79	0.03	0.00	3Z	1.57	0.40	2.64	1.06	5.01	6.16	64	
C140	C139	34	15	533.66	533.32	1.00	538.56	4.13	534.43	534.17	.00700	0.24	4.41	0.30	-0.21	0.23	0.00	4Z	1.21	0.15	2.64	0.40	5.41	6.46	65	
C139	C138	151	15	532.03	522.99	5.99	538.34	5.78	532.56	523.91	.00820	1.24	4.78	0.35	0.10	0.07	0.00	4Z	1.21	0.17	2.64	0.45	5.86	15.81	66	
C138	C137	34	15	522.79	522.45	1.00	527.60	3.69	523.91	523.09	.01100	0.37	5.51	0.47	0.22	0.23	0.00	6Z	0.50	0.34	2.64	0.90	6.76	6.46	67	
C137	A125	133	15	522.25	519.32	2.20	527.60	4.51	523.09	519.39	.01380	1.83	6.18	0.59	0.23	0.00	0.00	6Z	0.50	0.31	2.64	0.82	7.58	9.59	68	FR/ C145 0.01 BYP
C146	C129	54	15	528.00	527.46	1.00	532.83	4.43	528.40	527.86	.00050	0.03	1.21	0.02	0.03	0.00	0.00	2Z	1.93	0.56	2.64	1.48	1.48	6.46	69	
A134	A133	100	12	540.00	535.00	5.00	544.40	3.93	540.47	535.76	.01020	1.02	4.57	0.32	0.43	0.00	0.00	3S	8.25	1.36	2.64	3.59	3.59	7.97	70	
A133	DA132	219	18	534.80	528.78	2.75	540.60	4.84	535.76	530.10	.01500	3.28	7.27	0.82	0.97	0.02	0.00	3S	8.25	3.51	2.64	9.26	12.85	17.42	71	
DA132	A131	34	24	528.58	528.24	1.00	535.00	4.90	530.10	529.31	.00680	0.23	5.94	0.55	-0.01	0.57	0.00	4S	11.00	2.20	2.64	5.80	18.65	22.62	72	
A131	MH30	110	24	528.04	526.94	1.00	533.60	4.29	529.31	527.70	.00890	0.98	6.79	0.72	0.32	0.31	0.00	4S	11.00	1.02	2.64	2.69	21.34	22.62	73	
MH30	C129	78	24	526.74	525.96	1.00	534.20	6.50	527.70	526.54	.00890	0.69	6.79	0.72	0.00	0.47	0.00		0.00	0.00	0.00	0.00	21.34	22.62	74	
C129	C128	34	27	525.76	525.42	1.00	532.35	5.81	526.54	525.96	.00570	0.20	5.91	0.54	-0.09	0.47	0.00	2Z	1.93	0.25	2.64	0.66	23.48	30.97	75	
C128	C127	75	27	525.22	524.47	1.00	532.32	6.36	525.96	525.11	.00610	0.45	6.06	0.57	0.06	0.34	0.00	2Z	1.93	0.24	2.64	0.63	24.11	30.97	76	
C127	A126	123	27	524.27	523.04	1.00	531.09	5.98	525.11	524.21	.00630	0.77	6.17	0.59	0.04	0.09	0.00	2Z	1.93	0.16	2.64	0.42	24.53	30.97	77	
A126	A125	220	27	522.84	519.32	1.60	530.30	6.09	524.21	519.39	.00780	1.71	6.87	0.73	0.27	0.70	0.00	2S	5.50	1.06	2.64	2.80	27.33	39.18	78	
A125	A124	147	27	519.12	514.40	3.21	524.50	5.11	519.39	515.71	.01470	2.16	9.45	1.39	0.99	0.53	0.00	3S	8.25	1.01	2.64	2.67	37.58	55.50	79	
A124	A123	103	27	514.20	511.01	3.10	520.50	4.79	515.71	513.31	.01720	1.77	10.21	1.62	0.44	0.19	0.00	3S	8.25	0.45	2.64	1.19	40.59	54.50	80	
A123	FE22	44	30	510.81	510.37	1.00	516.50	3.19	513.31	509.32	.01050	0.46	8.54	1.13	-0.33	0.79	0.00	2S	5.50	0.56	2.64	1.48	41.94	41.02	81	
C119	A17	179	12	516.34	507.20	5.11	521.75	5.15	516.60	509.24	.00120	0.21	1.54	0.04	0.05	0.00	0.00	LOW	4.00	0.46	2.64	1.21	1.21	8.05	82	
A120	A112	150	12	516.80	515.30	1.00	521.80	2.10	519.70	518.77	.00480	0.73	3.16	0.15	0.20	0.00	0.00	2S	5.50	0.94	2.64	2.48	2.48	3.56	83	
A121	A117	236	12	528.95	524.70	1.80	535.00	4.94	530.06	527.11	.01060	2.50	4.67	0.34	0.45	0.00	0.00	3S	8.25	1.39	2.64	3.67	3.67	4.78	84	
FE18	A117	73	30	526.00	524.70	1.78	0.00	0.00	529.45	527.11	.01080	0.78	8.66	1.17	1.56	0.00	0.00	LOW	42.53	16.11	2.64	42.53	42.53	54.74	85	
A117	C116	133	36	524.50	523.17	1.00	530.50	3.39	527.11	525.32	.00570	0.75	7.11	0.78	-0.18	1.22	0.00	4S	11.00	1.54	2.64	4.06	50.25	66.70	86	
C116	C115	34	36	522.97	522.63	1.00	531.01	5.69	525.32	524.96	.00620	0.21	7.40	0.85	0.13	0.02	0.00	LOW	4.00	0.78	2.64	2.06	52.32	66.70	87	
C115	MH14	53	36	522.43	521.90	1.00	531.01	6.05	524.96	523.91	.00660	0.35	7.66	0.91	0.12	0.58	0.00	LOW	4.00	0.69	2.64	1.82	54.14	66.69	88	
MH14	A113	120	36	521.70	518.61	2.58	532.20	10.47	521.73	520.35	.00660	0.79	7.66	0.91	0.00	0.59	0.00		0.00	0.00	0.00	0.00	54.14	107.03	89	
A113	A112	106	36	518.41	514.40	3.78	526.60	6.25	520.35	518.77	.00720	0.77	8.02	1.00	0.17	0.64	0.00	3S	8.25	0.96	2.64	2.53	56.67	129.73	90	
A112	MH11	125	36	514.20	512.95	1.00	520.80	2.03	518.77	516.54	.00870	1.09	8.82	1.21	0.39	0.75	0.00	4S	11.00	1.22	2.64	3.22	62.37	66.70	91	

MH11	C110	55	36	512.75	512.20	1.00	521.20	4.66	516.54	515.21	.00870	0.48	8.82	1.21	0.00	0.85	0.00		0.00	0.00	0.00	0.00	62.37	66.70	92
CI10	C19	34	36	512.00	511.66	1.00	520.39	5.18	515.21	513.87	.00950	0.32	9.17	1.31	0.20	0.82	0.00	LOW	4.00	0.94	2.64	2.48	64.85	66.70	93
CI9	MH8	52	36	511.46	510.46	1.11 1.92	520.39	6.52	513.87	512.29	.01000	0.52	9.43	1.38	0.14	0.92	0.00	LOW	4.00	0.69	2.64	1.82	66.67	92.49	94
MH8	A17	208	36	510.26	507.20	1.91 1.47	521.30	9.01	512.29	509.24	.01000	2.08	9.43	1.38	0.00	0.97	0.00		0.00	0.00	0.00	0.00	66.67	80.90	95
A17	G16	90	36	506.99	503.10	4.32	514.00	4.76	509.24	507.71	.01070	0.97	9.77	1.48	0.20	0.36	0.00	3S	8.25	0.45	2.64	1.19	69.07	138.67	96
G16	FE5	145	42	502.90	500.00	2.00	510.20	2.49	507.71	507.00	.00490	0.71	7.30	0.83	-0.04	0.04	0.00	LOW	4.00	0.46	2.64	1.21	70.28	142.28	97
CI4	FE3	180	12	519.00	510.00	5.00	525.25	5.89	519.36	511.00	.00400	0.71	2.85	0.13	0.17	0.00	0.00	LOW	4.00	0.85	2.64	2.24	2.24	7.97	98
A12	MH1A	145	12	521.91	513.30	5.94	530.60	8.41	522.19	513.30	.00200	0.29	2.01	0.06	0.08	0.00	0.00	2S	5.50	0.60	2.64	1.58	1.58	8.68	99
MH1A	FE1	100	12	513.10	512.10	1.00	518.80	5.50	513.30	513.10	.00200	0.20	2.01	0.06	0.00	0.00	0.00		0.00	0.00	0.00	0.00	1.58	3.56	100
DS50	FE49	40	30	505.00	504.00	2.50	509.50	-1.61	511.11	506.50	.02500	1.00	13.20	2.71	3.61	0.00	0.00		64.81	0.00	0.00	64.81	64.81	64.85	101
DS60B	FE60A	80	48	504.80	504.00	1.00	519.00	8.84	510.16	508.00	.00620	0.49	8.97	1.25	1.67	0.00	0.00		112.70	0.00	0.00	112.70	112.70	143.64	102

69.95
91.94