

NOTE: ALL PROPER SAFETY ATTIRE SHALL BE WORN WHILE WORKING WITHIN M&DOT RIGHT OF WAY LIMITS.

WATER NOTE

- ALL WATER MAINS SHALL HAVE A MINIMUM OF 42" COVER.
- DOUBLE WATER METER SETUPS WILL BE REQUIRED WITH A SINGLE SERVICE LINE TO EACH METER.
- ALL WATER MAINS THAT CROSS UNDER THE PAVEMENT OR LIE WITHIN THE 1:1 SHEAR PLANE OF THE PAVEMENT SHALL PROVIDE 1" MINUS GRANULAR BACKFILL WITHIN THE TRENCH.

UTILITIES NOTE


UNDERGROUND FACILITIES, UTILITIES AND STRUCTURES HAVE BEEN PLOTTED FROM AVAILABLE INFORMATION AND THEREFORE, THEIR LOCATION MUST BE CONSIDERED APPROXIMATE ONLY. THERE MAY BE OTHERS, THE EXISTENCE OF WHICH IS PRESENTLY NOT KNOWN. IT IS THE RESPONSIBILITY OF THE CONTRACTOR TO HAVE ALL UTILITIES LOCATED IN THE FIELD PRIOR TO EXCAVATION OR CONSTRUCTION.

PWSD#2 WATER NOTES

1. The water system shall be installed in accordance with the latest Guidelines and Specifications of Public Water Supply District No. 2 of St. Charles County.
2. Public Water Supply District No. 2 of St. Charles County specifications are on file with the Missouri Department of Natural Resources. Please refer to specifications Review Number: 6050805-13
3. Public Water Supply District No. 2 of St. Charles County requires a minimum of one (1) week's notice prior to beginning construction of water mains.

WATER CIRCLE NOTES

- 1 FIRE HYDRANT WITH VALVE, PER DETAILS ON SHEET 56
- 2 8"x8"x8" TEE
- 3 8"x8"x6" TEE
- 4 8" - 6" REDUCER
- 5 8" WATER VALVE
- 6 6" WATER VALVE
- 7 90° BEND
- 8 45° BEND
- 9 22.5° BEND
- 10 11.25° BEND
- 11 WATER MAIN TERMINATION, SEE DETAILS ON 56.



CITY OF O'FALLON
 COMMUNITY DEVELOPMENT DEPARTMENT
 ACCEPTED FOR CONSTRUCTION
 BY: [Signature] DATE **December 6, 2016**
 PROFESSIONAL ENGINEER'S SEAL
 INDICATES RESPONSIBILITY FOR DESIGN

City of O'Fallon Standard Subdivision Notes and Details - June 2010

PROJECT TITLE
**IMPROVEMENT PLANS
 THE VILLAGES AT
 MONTRACHET (REVISED)**
 WATER PLAN
 PFS No. 14055MCH000R,
 TASK 017 FIELD BOOK 1476

PICKETT, RAY & SILVER INC
 CIVIL ENGINEERING, LAND SURVEYING,
 AND NATURAL RESOURCES SERVICES
 St. Peters
 22 Richmond Center Court
 St. Peters, MO 63376
 Phone (636) 397-1211 Fax (636) 397-1104
 www.prsas.com 1-800-708-3918

ENGINEER'S AUTHENTICATION
 THE RESPONSIBILITY FOR PROFESSIONAL ENGINEERING
 LIABILITY ON THIS PROJECT IS STRICTLY LIMITED TO THE
 SET OF PLANS AUTHENTICATED BY THE SEAL, SIGNATURE,
 AND DATE HEREON ATTACHED. RESPONSIBILITY IS
 DISCLAIMED FOR ALL OTHER ENGINEERING PLANS
 PROVIDED IN THIS PROJECT AND SPECIFICALLY EXCLUDES
 REVISIONS AFTER THIS DATE UNLESS REAUTHENTICATED.
PICKETT, RAY & SILVER, INC. MO. NO. 000038

 KARL A. SCHOENIKE, P.E.
 PROFESSIONAL ENGINEER LICENSE 2003015039
 ELECTRONIC SEAL
 12/06/16

Developer / Owner Information
MONTRACHET DEVELOPMENT LLC
 218 Chesterfield Towne Centre
 Chesterfield, Missouri 63005
 Phone: 636-550-6900

P+Z No. 15-15.01

City No.
 15-742-SP

Page No.
 WATER PLAN
18 of 63

CITY OF O'FALLON REVISED MONTRACHET DRIVE 12/06/2016

P:\14055MCH000R\Design\Output\Improvement Plans REVISED PHASE A 04-14055 WATER.dwg