

U.S. HIGHWAY NO. 79

FIRMA

ROAD

MAIN OFFICE BUILDING

CONTRACTOR SHALL ARRANGE COORDINATE AND COMPENSATE MISSOURI EDISON POWER COMPANY AS REQUIRED FOR ADJUSTMENTS TO AND RELOCATION OF THE EXISTING OVERHEAD POWER LINE

BAD MTD TRAHOP.

BIO-FILTER COMPLEX

PRIMARY CLARIFIER NO. 1

PRIMARY CLARIFIER NO. 2

AERATION TANKS

FINAL CLARIFIER NO. 1

FINAL CLARIFIER NO. 2

COMMINUTOR & METER VAULT

EXIST. BLOWER BUILDING

EXISTING AEROBIC DIGESTER

CREEK


PERUQUE

NOTE: SEE SHT. #40 FOR SPECIFIC MOUNTING LOCATIONS OF DISC. SW. & LIGHT POLE AT FINAL CLARIFIERS

NOTE: PULL BOXES SHALL BE INSTALLED AT INTERVALS OF 75' IN ALL CIRCUITS UNLESS SHOWN OTHERWISE SEE SHT. #EB FOR PULL BOX & POLE BASE DETAILS.

ELECTRICAL CONTR SHALL INSTALL ALARM PANEL AND HORN AT EA CLARIFIER FURNISHED BY GEN CONTR

NOTE: SEE SHT. #10 FOR SPECIFIC MOUNTING LOCATIONS OF DISC. SW. & LIGHT POLE AT PRIMARY CLARIFIERS.



SCALE: 1" = 50'

EPA PROJECT NO. C291090

Rev. 3-82 MKK

EI

GBA

GEORGE BUTLER ASSOCIATES
CONSULTING ENGINEERS/ARCHITECTS
LANDSCAPE ARCHITECTS/PLANNERS

OFFICES:
SUITE 305-A FAIRWAY OFFICE CENTER
4210 JOHNSON DRIVE / SHAWNEE MISSION / KANSAS 66205
1100 CITY CENTER SQUARE
1100 MAIN / KANSAS CITY / MISSOURI 64105
SUITE 134 LAKESIDE PLAZA II
6700 CORPORATE DRIVE / KANSAS CITY / MISSOURI 64120

WASTE WATER TREATMENT
PLANT EXPANSION

ELECTRICAL SITE PLAN

CITY OF O'FALLON, MISSOURI

DESIGNED BY: DBR

DRAWN BY:

CHECKED BY: HHJ

JOB NO. 79-2065

DATE 30 JULY 81

SCALE 1" = 50'

SHEET NO. 80 OF 88