



- NOTES:**
- Existing aerators and associated equipment to be removed and replaced with new process equipment. Typical for Aeration Tanks No. 1, No. 2 and No. 3. See sheet C25.02 for New Equipment arrangement.
  - 20" DIP from Distribution Box No. 2 to Aeration Tank No. 3 to be abandoned in place except where it is necessary to remove to make piping modifications. (See Sheet C19.01)
  - Existing 20" Valve to be removed and re-used. Location is to be between Aeration Tank No. 3 and New 20" MJ Tee
  - Existing 20" DIP to be abandoned in place except where necessary to remove for piping modifications.
  - All piping to be abandoned in place shall have both ends concrete fill capped.
  - No more than one (1) Aeration Tank shall be Out of Service a Maximum of 6 Hours. Details of Construction Phasing of the Aeration Tank and Associated piping Shall be Submitted from the Contractor to the Engineer for Approval. This Approval MUST be received from the Engineer Prior to beginning construction of the Aeration Tank and Piping Improvements.

- NOTES:**
- The Contractor shall field verify all dimensions and elevations and submit a layout plan for equipment and fittings selected for review with the shop drawings.
  - Existing 36" Piping to be removed to a point where the 36" MJ Wye is to be installed.

**PLAN - AERATION TANKS AND ADJACENT STRUCTURES**

SCALE 3/16" = 1'-0"