



PARTIAL LIGHTING PLAN
3/16" = 1'-0"

- NOTES:**
- SEE DRAWING M1 FOR ELECTRICAL LEGEND & ABBREVIATIONS AND GENERAL REQUIREMENTS.
 - SEE DRAWING M18 FOR LIGHTING FIXTURE SCHEDULE.
 - MULTI-OUTLET STRIP, 5'-0" LONG WITH (5) SINGLE 20A RECEPTACLES ON 12" CENTERS. WIREMOLD #V24GB512.
 - EMERGENCY LIGHTING UNIT REMOTE HEAD MOUNTED NEXT TO FIXTURE.
 - WORKSTATION CONSOLE SHALL BE EQUIPPED WITH A 30A 120V1P NEMA L5-30P RECEPTACLE FOR THE UPS SYSTEM. SIX DATA OUTLETS, AND TWO VOICE OUTLETS AS INDICATED.

MATCHLINE - SEE DRAWING M16

NO.	DATE	CONFORMED TO CONSTRUCTION RECORDS	ADDENDUM	REVISIONS AND RECORD OF ISSUE	NO.	BY	CHK	APP
2					1			

THIS DRAWING WAS ORIGINALLY APPROVED FOR CONSTRUCTION BY JOSEPH T. FORBES ON 10/08/01 AND SEALED BY JOSEPH T. FORBES A LICENSED PROFESSIONAL ENGINEER IN THE STATE OF MISSOURI, NO. E-27568

BLACK & VEATCH
Corporation
St. Louis, Missouri

CITY OF O'FALLON, MISSOURI
WATER TREATMENT PLANT
ELECTRICAL OPERATIONS BUILDING
PARTIAL LIGHTING PLAN

DESIGNED: DAH
DETAILED: DAH, BAL
CHECKED: KHI
APPROVED: [Signature]
DATE: 10/08/01

PROJECT NO.
97515

M16
SHEET
71 OF 96