



PARTIAL FLOOR PLAN
3/16" = 1'-0"

- NOTES:**
- SEE DRAWING M1 FOR ELECTRICAL LEGEND & ABBREVIATIONS AND GENERAL REQUIREMENTS.
 - PROVIDE DISCONNECTS FOR 120V POWER TO EACH GAS UNIT HEATER, AND AS INDICATED ON ONE-LINE DRAWINGS.
 - R.O. PLC PROVIDED BY R.O. SYSTEM SUPPLIER. EXACT LOCATION DETERMINED BY R.O. SYSTEM SUPPLIER.

NO.	BY	CHK.	APP.
2	JTF		
1	JTF		

CONFORMED TO CONSTRUCTION RECORDS
ADDENDUM

DATE	REVISIONS AND RECORD OF ISSUE
CYGNET ID: 97515-300-E-100000000A	XREF1 ID: 97515-300-E-100000000A
SAVED: 1/14/44289, 10/20/2004 2:18:05 PM	XREF2 ID: 97515-300-A-100000000A
DWG VER #: 1	XREF3 ID: 97515-300-H-100000000H
PLOTTED: 1/14/44289, 10/20/2004 2:14:23 PM	XREF4 ID: 97515-300-C-100000000C
USER: 1/14/44289	USER: 1/14/44289

*THIS DRAWING WAS
ORIGINALLY PROVIDED
BY JOSEPH T. FORBES ON
10/08/01 AND SEALED
BY JOSEPH T. FORBES
A LICENSED PROFESSIONAL
ENGINEER IN THE
STATE OF MISSOURI,
NO. E-27588*



CITY OF O'FALLON, MISSOURI
WATER TREATMENT PLANT
ELECTRICAL OPERATIONS BUILDING
PARTIAL POWER PLAN

DESIGNED: GNS
DETAILED: DAH, BAL
CHECKED: KHI
APPROVED: JTF
DATE: 10/08/01

PROJECT NO.
97515
M14
SHEET
OF 96