



PAC-101 PARTIAL PLAN
3/16" = 1'-0"

- NOTES:**
- SEE DRAWING M1 FOR ELECTRICAL LEGEND & ABBREVIATIONS AND GENERAL REQUIREMENTS.
 - ROOMS 119, 120, 123, AND 125 SHALL INCLUDE FIRE PROTECTION AND ALARM.
 - PROVIDE DISCONNECTS FOR 120V POWER TO EACH GAS UNIT HEATER, AND AS INDICATED ON ONE-LINE DIAGRAMS.
 - AFD'S FOR RO FEED PUMPS SHALL FIT IN SPACE INDICATED. ALTERNATIVE EQUIPMENT ARRANGEMENTS MAY BE CONSIDERED AND SHALL BE APPROVED BY ENGINEER.
 - EMERGENCY EYE WASH STATIONS WILL BE PROVIDED WITH FREEZE PROTECTION (HEAT TRACING) BY OTHERS.

MATCHLINE - SEE DRAWING M14

PARTIAL POWER PLAN
3/16" = 1'-0"

CONFORMED TO CONSTRUCTION RECORDS		REVISIONS AND RECORD OF ISSUE		NO. BY CK APP	
DATE	ADDENDUM	NO.	BY	NO.	BY
9/7/15	1	1	CK	1	CK
10/8/15	2	2	CK	2	CK

THIS DRAWING WAS ORIGINALLY APPROVED FOR CONSTRUCTION BY JOSEPH T. FORBES ON 10/08/01 AND SEALED BY JOSEPH T. FORBES, A LICENSED PROFESSIONAL ELECTRICAL ENGINEER IN THE STATE OF MISSOURI, NO. E-27568.

BLACK & VEATCH
CORPORATION
St. Louis, Missouri

CITY OF O'FALLON, MISSOURI
WATER TREATMENT PLANT
ELECTRICAL OPERATIONS BUILDING
PARTIAL POWER PLAN

DESIGNED: GNS
 DETAILED: DAH, BAL
 CHECKED: KHI
 APPROVED: JTF
 DATE: 10/08/01

PROJECT NO.
97515

M15

SHEET
70 OF 96