



- PLAN NOTES:**
- 1 2" D DN TO FR.
  - 2 ROUTE 2" D TIGHT TO UNDERSIDE OF ELEVATED SLAB. ENCASE WITH 6" OF CONCRETE.
  - 3 3" FD-4, TOP EL 441.92.
  - 4 USE COMBINATION Y AND EIGHTH BAND TO ROUTE VENT PIPE OFF OF THE SAN MAIN.
  - 5 WH SHALL HAVE THEIR OWN INDEPENDENT SV LOCATED INSIDE THE BLDG.
  - 6 SV IN RISER 6' AFF.

CONFORMED TO CONSTRUCTION RECORDS	NO.	BY	CHK
ADDENDUM	2	1	1
DATE	REVISED AND RECORD OF ISSUE		
CYNET ID: 97515-300-FB-10000000	XREF1 ID: A-10000000CAJ		
SAVED: 1/4/2004 10:28:10 PM	XREF2 ID: A-1000000000		
DWG VER #: 1/4/2004 1:38:01 PM	XREF3 ID: H-100000009M		
PLOTTED: 1/4/2004 1:38:01 PM	XREF4 ID: H-100000009M		
USER: 1/4/2004	XREF5 ID: FB-100000005C		

\*THIS DRAWING WAS ORIGINALLY APPROVED FOR CONSTRUCTION BY DAVID W. NELSON ON 10/08/01 AND SEALED BY DAVID W. NELSON A LICENSED PROFESSIONAL ENGINEER IN THE STATE OF MISSOURI, NO. E-29940\*



**CITY OF FALLON, MISSOURI**  
**WATER TREATMENT PLANT**  
**MECHANICAL - PLUMBING**  
**PARTIAL OPERATING FLOOR PLAN - NORTH**

DESIGNED: BCD
DETAILED: BDL, JMC
CHECKED: MLP
APPROVED: DWN
DATE: 10/08/01
PROJECT NO.

97515

K3

SHEET 48 OF 96