



THIS DRAWING WAS ORIGINALLY APPROVED FOR CONSTRUCTION BY EDWARD D. VOST ON 10-08-2001 AND SEALED BY EDWARD D. VOST AS A LICENSED PROFESSIONAL ENGINEER IN THE STATE OF MISSOURI, NO. E-28417.

THIS DRAWING WAS ORIGINALLY APPROVED FOR CONSTRUCTION BY EDWARD D. VOST ON 10-08-2001 AND SEALED BY EDWARD D. VOST AS A LICENSED PROFESSIONAL ENGINEER IN THE STATE OF MISSOURI, NO. E-089790.



CITY OF FALLON, MISSOURI
 WATER TREATMENT PLANT
 SODIUM HYPOCHLORITE FEED SYSTEM
 P&ID

DESIGNED: SMM
 DETAILED: SMM
 CHECKED: DCG
 APPROVED: EDV
 DATE: 10/08/01

PROJECT NO.
 97515

N15

SHEET
 88 OF 96

NO.	BY	CHK	APP
1			
2			
CONFORMED TO CONSTRUCTION RECORDS			
ADDENDUM			
REVISIONS AND RECORD OF ISSUE			
DATE	BY	CHK	APP
CYBNET ID: 97515-300-E-T060002M			
SAVED:			
DWG VER #:			
PLOTTED:			
USER:			

- NOTES:
1. LOCATE P-TRAP FILL VALVE NO MORE THAN 5 FEET ABOVE FINISHED FLOOR.
 2. SODIUM HYPOCHLORITE METERING PUMP SUCTION PIPING SHALL BE ROUTED TO SLOPE DOWNWARD FROM DAY TANK WITHOUT HIGH POINTS OR LOW POINTS.

SODIUM HYPOCHLORITE FEED SYSTEM