



IF THE STORM AND SANITARY SEWERS ARE PARALLEL AND IN THE SAME TRENCH OR OVERDIP, THE UPPER PIPE SHALL BE PLACED ON A SHELF AND THE LOWER PIPE SHALL BE BEDDED IN COMPACTED GRANULAR FILL TO THE FLOW LINE OF THE UPPER PIPE.

ALL SANITARY LATERAL STREET CROSSINGS, IF TRENCHED, SHALL BE BACKFILLED WITH GRANULAR MATERIAL (AGGREGATE).

STORM SEWER PIPES WHICH CROSS OVER EXISTING OR PROPOSED SANITARY SEWER TRENCHES SHALL BE CONCRETE THROUGH THE FULL WIDTH OF THE SANITARY SEWER TRENCH. THE TRENCH SHALL BE BACKFILLED AND COMPACTED GRANULAR FILL TO THE BOTTOM OF THE CONCRETE CRADLE.

HORIZONTAL SCALE: 1" = 50'
 VERTICAL SCALE: 1" = 10'

PICKETT RAY & SILVER
 CIVIL ENGINEERS
 PLANNERS
 LAND SURVEYORS

333 Mid Rivers Mall Drive
 St. Peters, MO 63376
 Phone (636) 397-1211
 Fax (636) 397-1104

WELLINGTON PARK
 SANITARY SEWER PROFILES

THE JONES COMPANY
 Building Humans Since 1927
 A CENTEX Company

16640 Chatterfield Grove Blvd
 Chesterfield, MO 63005
 (314) 255-7587

REVISIONS NO.	DATE	DESCRIPTION	BY
1	05/13/03	REVISED STORM SEWER LAYOUT AT NORTH ENTRANCE	
2	04/23/03	REVISED PER DUCKETT CREEK SANITARY DISTRICT	
3	04/20/03	REVISED PER DUCKETT CREEK SANITARY DISTRICT	

DRAWN	E.J.S.	DATE	03-04-03
CHECKED		DATE	
PROJECT #	02077.JCCH.OOR	TASK #	6
	FIELD 1997B	BOOK	821

I:\swwer\proj\02077\02077.dwg, 03/04/03, 11:11 AM, X328860.pct, R.D. Wiggs