

NOTES

1. Fixtures at 32' (30' pole with 2' base) Floods at 10'


STATISTICS

Description	Symbol	Avg	Max	Min	Max/Min	Avg/Min
Area of Tresspass	+	0.1 fc	3.0 fc	0.0 fc	N/A	N/A
Wendy's Lot	+	3.1 fc	15.3 fc	0.2 fc	76.5:1	15.5:1

LUMINAIRE SCHEDULE

Symbol	Label	Qty	Catalog Number	Description	Lamp	File	Lumens	LLF	Watts
○	A	5	KVF 1000M ASY/EHS	SQUARE AREA LIGHT, ASYMMETRIC DISTRIBUTION, FLAT LENS, HOUSE SIDE SHIELD.	ONE 1000-WATT CLEAR BT-37 METAL HALIDE VERTICAL BASE-UP POSITION.	LTL1574.88	110000	0.74	1080
□	B	6	KFL3 320M HPM	ARCHITECTURAL FLOODLIGHT, HPM DISTRIBUTION, 320W MH, W/ CLEAR LAMP.	ONE 320-WATT CLEAR EQ-24 METAL HALIDE HORIZONTAL POS.	SH20029.IES	29700	0.74	462

NOTE:
 ALL POST TOP SITE LIGHTING MUST BE AIMED AND SHIELDED SO THAT THE AMBIENT LIGHT LEVELS ON THIS SITE DO NOT EXCEED 25fc AT THE PROPERTY LINE. IT IS THE CONTRACTOR'S RESPONSIBILITY TO PROVIDE REAR AND SIDE SHIELDS AFTER INSTALLATION TO ACHIEVE THIS CITY REQUIREMENT.



143 West Clinton Place
 St. Louis Missouri 63122
 (ph) 966-7446 (fax) 966-7477

Proposed:
Wendy's
 OLD FASHIONED HAMBURGERS
 1390 Mexico Loop Road East
 O'Fallon, MO

ELECTRICAL PHOTOMETRIC PLAN SCALE: NONE

NO: #0748	Revision:	Date:	Dr:
DATE: 04/16/08	ADDITION # OWNER CHANGES	07/03/08	PL
DR: S. SEAGRASS			
CK: P. WILSON			

