















ROUND PIPE				HORIZONTAL ELLIPTICAL PIPE			
INSIDE DIAMETER (INCHES)	"W" PAYLINE WIDTH OF TRENCH (INCHES)	"T" PAYLINE WIDTH OF TRENCH (FEET)	PAY-VOLUMES (CU. FT. PER FT.)	INSIDE DIMENSIONS OF PIPE (INCHES)	"W" PAYLINE WIDTH OF TRENCH (INCHES)	"T" PAYLINE WIDTH OF TRENCH (FEET)	PAY-VOLUMES (CU. FT. PER FT.)
4	30	2.50	3.28				
6	30	2.50	3.99				
8	30	2.50	3.87				
10	30	2.50	4.09				
12	30	2.50	4.25				
15	36	3.00	5.55				
18	36	3.00	5.77	14 x 23	41	3.42	5.94
21	39	3.25	6.61				
24	42	3.50	7.39	19 x 30	49	4.08	7.68
27	45	3.75	8.18	22 x 34	53	4.42	8.81
30	48	4.08	9.30	24 x 38	59	4.83	9.70
33	53	4.42	10.53	27 x 42	62	5.17	10.71
36	56	4.87	11.43	29 x 45	66	5.50	11.72
39	63	5.25	12.38	32 x 49	71	5.92	13.14
42	63	5.25	13.38	34 x 53	75	6.25	14.05
48	70	5.83	15.67	38 x 60	83	6.92	16.18
54	77	6.42	18.15	43 x 68	92	7.67	18.81
60	84	7.00	20.73	48 x 76	101	8.42	21.59
66	91	7.58	23.45	53 x 83	109	9.08	24.33
72	98	8.17	26.37	58 x 91	118	9.83	27.45
78	105	8.75	29.39	63 x 98	126	10.50	30.50
84	112	9.33	32.57	68 x 106	135	11.25	33.61
90	119	9.92	35.90	72 x 113	143	11.92	36.89
96	126	10.50	39.37	77 x 121	152	12.67	40.69
102	133	11.08	42.99	82 x 128	160	13.33	44.45
108	140	11.67	46.75	87 x 136	168	14.00	47.79
114	147	12.25	50.66	92 x 143	176	14.67	51.70
120	154	12.83	54.72	97 x 151	185	15.42	56.01
126	161	13.42	58.92				
132	168	14.00	63.27	108 x 166	202	16.83	64.48
144	182	15.17	72.40	116 x 180	218	18.17	72.89

TABLE 1
PAYLINE WIDTHS OF TRENCH AND PAY-VOLUMES OF CONCRETE

METROPOLITAN ST. LOUIS SEWER DISTRICT
Standard Details of Sewer Construction
Dr. S.A.M. Ch. P.W.S. 2000 SHEET 1



PRECAST CONCRETE STORMWATER STRUCTURES

MINIMUM DISTANCE FLOWLINE TO TOP OF STONE OR GRATE

PIPE DIA. NOMINAL INCHES	MIN. INLET CIRCULAR BASE DIA. (MAX.)	1/2" GRATE INLET CIRCULAR BASE DIA. (MAX.)	BRICK SILL INLET CIRCULAR BASE DIA. (MAX.)
12"	48"	48"	48"
15"	48"	48"	48"
18"	54"	48"	48"
21"	55"	48"	48"
24"	58"	51"	48"
27"	58"	51"	48"
30"	60"	51"	48"
33"	60"	51"	48"
36"	60"	51"	48"
42"	60"	51"	48"

PRECAST CONCRETE STORMWATER STRUCTURES

METROPOLITAN ST. LOUIS SEWER DISTRICT
Standard Details of Sewer Construction
Dr. J.L.G. Ch. J.C.K. 2000 SHEET 34

