STANDARD METER INSTALLATION



MATERIAL LIST - 1" WATER METER SERVICE

1" Sensus SRII MTR, TRPL, 100 GL PLAS BNT

1" Meter Yoke with 12" Rise and Locking Ball Valve (B2404-1")

1" Corporation Stop (B25008-1")

2 - 1" End Connectors, Compression (H-14227-1")

20 6150 MTR Box Cover LN w/TR

20" x 30" Meter Tile (MIDSTATES)

1" x 8" Tapping Saddle, PVC (H13433-1")

1" x 10" Tapping Saddle, PVC (H13434-1")

1" x 6" Tapping Saddle, PVC



STANDARD BLOW-OFF



FIRE HYDRANT DETAILS

NOTE SEE SPECIAL CONDITIONS



DETAILS
THRUST BLOCK FOR HORIZONTAL OFFSETS

PIPE DIA	90° BENDS		45° BENDS		22.5° BENDS		WYES & TEES	
DIM.	B	D	B	D	B	D	B	D
2"	1.0	0.7	1.0	0.7	1.0	0.7	1.0	0.7
3"	1.0	0.7	1.0	0.7	1.0	0.7	1.0	0.7
4"	1.0	0.7	1.0	0.7	1.0	0.7	1.0	0.7
6"	1.6	1.0	1.0	1.0	1.0	1.0	1.0	1.0
8"	1.8	1.0	1.4	1.0	1.0	1.0	2.5	1.0
10"	2.3	1.2	1.7	1.2	1.2	1.2	3.1	1.2
12"	2.7	1.4	2.0	1.4	1.4	1.4	3.6	1.4
14"	3.2	1.5	2.4	1.5	1.5	1.5	4.1	1.5
16"	3.6	1.7	2.7	1.7	1.9	1.7	4.7	1.7

UNDISTURBED EARTH

16" SOLID CONCRETE BLOCK

Determine size of B from above thrust blocks dimensions unless poor soil conditions (organics, saturated clay, etc.) dictate larger thrust area center of mass

THRUST BLOCKS
NOT TO SCALE



NOTE:
IF AMERICAN DARLING FIRE HYDRANTS ARE TO BE USED, THE CONTRACTOR SHALL FURNISH TO THE CITY REPAIR PARTS, REBUILD KITS, AND WRENCHES FOR SEAT REMOVAL



TRENCH DETAIL