



- PUBLIC WATER SUPPLY DISTRICT NO. 2 NOTES:**
- Public Water Supply District #2 requires 1 week notice before construction begins.
 - All water mains, valves, fittings, hydrants, and related items are to be installed in accordance with the current St. Charles County Public Water Supply District #2 Guidelines and Specifications as approved by MDNR Review No. 6050805-13.
 - Public Water Supply District #2 requires a minimum of Class 200 (SDR 21) PVC pipe for its water mains.
 - It is the Contractor's responsibility to obtain any MoDOT, City, or County permits for work adjacent to Roadways. Copies of these permits must be given to the Water District prior to the start of construction.
 - Public fire hydrants will be required to be painted chrome yellow per the Water District's specifications.
 - All off-site restoration will be required to be restored with sod unless other consideration is requested by the off-site property owners.
 - All meter pits must be installed in "greenspace" per the Water District's specifications.
 - All existing inline and auxiliary valves must remain to grade during and after construction is complete.



PROJECT TITLE:
WYNDGATE MEADOWS

ENGINEERING PLANNING SURVEYING
 221 Point West Blvd.
 St. Charles, MO 63301
 636-928-5552
 FAX 636-928-1718



DISCLAIMER OF RESPONSIBILITY
 I hereby certify that the documents intended to be authenticated by my seal are limited to this sheet, and I hereby disclaim any responsibility for all other drawings, specifications, estimates, reports or other documents or instruments relating to or intended to be used for any part or parts of the architectural or engineering project.

STATE OF MISSOURI
 JEFFREY B. SIMMONS
 NUMBER PE-2007030831
 EXPIRES 12/31/2019
 PROFESSIONAL ENGINEER
 JEFFREY B. SIMMONS
 CIVIL ENGINEER
 2007030831
 Copyright 2019
 Box Engineering Company, Inc.
 Authority No. 000655
 All Rights Reserved

REVISIONS

DATE	DESCRIPTION
08/08/19	D.C.S.D. P.W.S.D. #2 & CLIENT COMMENTS
08/30/19	D.C.S.D. P.W.S.D. #2 & CITY COMMENTS
09/25/19	D.C.S.D. & CITY COMMENTS
10/22/19	CITY COMMENTS
11/08/19	CITY COMMENTS
11/22/19	CITY COMMENTS

Developer / Owner:
 STRACOR, L.L.C.
 9645 Clayton Road
 St. Louis, MO 63124
 314-667-9400

P+Z No. #18-012166
Approval Date: 06/27/2019
City No. #RSP-19-000010

Page No.
 6 of 25

Issue Date: 07/09/2019
 Box Project # 17-17314

WATER PLAN