



ZENON Environmental Inc.
 Oakville, Ontario 905-465-8030

DEC 23 2004

ISSUED FOR APPROVAL

By [Signature]

- NOTES:
1. ALL DOTTED LINES/EQUIPMENT BY OTHERS
 2. DRAWING TYPICAL FOR MEMBRANE TRAINS 1 TO 2.
 3. A HORIZONTAL RUN OF PIPE MUST EXIST A MINIMUM 24" ELEVATION ABOVE THE MAXIMUM WATER LEVEL.
 4. LEVEL SENSOR TO BE INSTALLED 2"-3" OFF THE DEEP END OF THE MEMBRANE TANK FLOOR, OR BELOW IT IF POSSIBLE (IN DRAIN SUMP).
 5. PORTABLE SUBMERSIBLE PUMP USED TO FULLY DRAIN TK-34-1 (BY OTHERS).

0	04/12/22	ISSUED FOR APPROVAL		L.S.	D.Z.
REV.	DATE	DESCRIPTION	ZONE	DSGN	APPD
APPROVAL	DATE (Y/M/D)	ZENON Environmental Inc. ZENON - OAKVILLE ONTARIO			
DRWN: E. D.	04/09/21				
DSGN: A. C.	04/05/21				
CHLD: A. C.	04/12/15				
APPD: D. Z.	04/12/15				
CADD FILE:	500292D004.DGN	CUSTOMER: DD HIGHWAY, MO	TITLE: PIPING & INSTRUMENTATION DIAGRAM MEMBRANE TANK & ASSOC. EQUIPMENT		
SCALE:	1:1	SIZE: D	DRAWING NO. 500292-D-004	SHEET 1 OF 1	REV. 0