



ZENON Environmental Inc.
Oakville, Ontario 905-455-3030

DEC 23 2004

ISSUED FOR APPROVAL

[Signature]

- NOTES:**
1. ALL DOTTED LINES/EQUIPMENT BY OTHERS
 2. DRAWING TYPICAL FOR PERMEATE PUMPS 1 TO 2.
 3. DESIGN ENGINEER TO ENSURE PERMEATE DISCHARGE HEADER REMAINS FLOODED AT ALL TIMES.
 4. FOR MAGNETER INSTALLATION INSTRUCTIONS REFER TO VENDOR DATA.
 5. FLOOR DRAINS TO BE PROVIDED BY OTHERS AS REQUIRED.

| REV. | DATE | DESCRIPTION | ZONE | DSGN | APPD |
|------------|----------------|---|--------------------------|--------------|--------------|
| 0 | 04/12/22 | ISSUED FOR APPROVAL | | L.S. | D.2. |
| APPROVAL | | DATE (Y/M/D) | ZONEN Environmental Inc. | | |
| DRWN: E.D. | 04/09/21 | ZEN - OAKVILLE ONTARIO | | | |
| DSGN: A.C. | 04/09/21 | CUSTOMER: DD HIGHWAY, MD | | | |
| CHKD: A.C. | 04/12/15 | TITLE: PIPING & INSTRUMENTATION DIAGRAM | | | |
| APPD: D.2. | 04/12/15 | PROCESS PUMP & ASSOC. EQUIPMENT | | | |
| CADD FILE: | 500292D005.DGN | SCALE: | 1:1 | DRAWING NO.: | 500292-0-005 |
| SHEET | | 1 OF 1 | | REV. | 0 |