

ZENON Environmental Inc.
 Oakville, Ontario 905-485-3030

DEC 23 2004
ISSUED FOR APPROVAL
[Signature]

- NOTES:
- ALL DOTTED LINES/EQUIPMENT BY OTHERS
 - A MINIMUM SPOOL LENGTH OF 2 PIPE DIAMETERS TO BE INSTALLED BETWEEN STRAINER AND ISOLATION VALVES FOR STRAINER REMOVAL.
 - DIAMETER OF THE PIPE WILL DEPEND ON DOWNSTREAM CONDITIONS. TO BE SIZED BY OTHERS.
 - THE CIP/PP TANK IS TO CONTAIN MINIMUM 1600 GALLONS TO ENSURE THAT PERMEATE FOR BACKPULSE IS ALWAYS AVAILABLE.
 - BACKPULSE TANK ELEVATION ASSUMED TO BE 10 FT HIGHER THAN PUMP CENTRE LINE.

0	04/12/22	ISSUED FOR APPROVAL		L.S.	D.Z.
REV.	DATE	DESCRIPTION	ZONE	DSGN	APPD
APPROVAL	DATE (Y/M/D)	 ZENON Environmental Inc. ZEN - OAKVILLE ONTARIO CUSTOMER: DD HIGHWAY, MO TITLE: PIPING & INSTRUMENTATION DIAGRAM PERMEATE POST-TREATMENT EQUIPMENT SHEET 1 OF 1			
DRWN:	04/09/21				
DSGN:	04/09/21				
CHKD:	04/12/15				
APPD:	04/12/15				
CADD FILE:	500292007.DGN	SCALE:	1:1	DRAWING NO.:	500292-D-007

THIS DOCUMENT CONTAINS DESIGN AND INFORMATION PROPRIETARY TO ZENON ENVIRONMENTAL, INC. IT IS TO BE USED ONLY FOR THE PURPOSE AND BY THE ENTITY FOR WHICH IT WAS ORIGINALLY SUPPLIED. THE DOCUMENT MAY NOT BE REPRODUCED, DISCLOSED TO ANY OTHER PERSON OR ENTITY, OR USED FOR MANUFACTURE OF THE ITEM IN WHOLE OR IN PART WITHOUT THE WRITTEN PERMISSION OF ZENON ENVIRONMENTAL, INC.